



# ULTRATEMP® HEAT PUMP



ENGLISH 1

FRANÇAIS 35

ESPAÑOL 73

## INSTALLATION AND USER'S GUIDE

IMPORTANT SAFETY INSTRUCTIONS  
*READ AND FOLLOW ALL INSTRUCTIONS*  
SAVE THESE INSTRUCTIONS



## CUSTOMER SERVICE / TECHNICAL SUPPORT

If you have questions about ordering Pentair Aquatic Systems, ("Pentair") replacement parts, and pool products, please use the following contact information:

**Customer Service** (8 A.M. to 4:30 P.M. — Eastern and Pacific Times)

Phone: (800) 831-7133

Fax: (800) 284-4151

**Web site**

visit [www.pentairpool.com](http://www.pentairpool.com) or [www.staritepool.com](http://www.staritepool.com) to find information about Pentair products.

**Technical Support**

**Sanford, North Carolina** (8 A.M. to 4:30 P.M. ET)

Phone: (919) 566-8000

Fax: (919) 566-8920

**Moorpark, California** (8 A.M. to 4:30 P.M. PT)

Phone: (805) 553-5000 (Ext. 5591)

Fax: (805) 553-5515

## TABLE OF CONTENTS

|                                                                          |            |                                                                      |           |
|--------------------------------------------------------------------------|------------|----------------------------------------------------------------------|-----------|
| <b>Important Warning and Safety Instructions .....</b>                   | <b>ii</b>  | <b>Operating the Heat Pump .....</b>                                 | <b>16</b> |
| <b>Menu Tree Quick Start Guide .....</b>                                 | <b>iii</b> | Swimming Pool Energy Saving Tips                                     | 16        |
| <b>Before Installing the Heat Pump .....</b>                             | <b>1</b>   | Heat Pump Control Panel Overview                                     | 16        |
| Heat Pump Overview                                                       | 1          | Operator Menu Tree Guide                                             | 17        |
| Installation Requirements                                                | 1          | Starting and Stopping the Heat Pump                                  | 18        |
| General Installation Information                                         | 1          | Changing the Set Point - Pool and Spa                                | 18        |
| General Features                                                         | 1          | Heat, Cool, and Auto Modes                                           | 18        |
| <b>Installation and Location .....</b>                                   | <b>2</b>   | Heat Pump Timer                                                      | 18        |
| Materials Needed for Installation                                        | 2          | Relay Remote                                                         | 18        |
| Equipment Pad                                                            | 2          | RS-485 Remote (Serial Cable)                                         | 18        |
| Drainage and Condensation, Roof Run Off,<br>and Lawn Sprinklers          | 2          | AutoSet Operation                                                    | 19        |
| Heat Pump Dimensions                                                     | 2          | Extend Operation                                                     | 19        |
| Location and Clearances                                                  | 3          | Timers and Delays                                                    | 20        |
| Anchor Clamp Installation                                                | 3          | Control Panel Alarm Messages                                         | 20        |
| Water Connections and Plumbing                                           | 4          | Service Menu Tree Guide                                              | 21        |
| Automatic Flow Control Valve                                             | 4          | Setting Temperature Scale                                            | 22        |
| Water Pressure Switch Adjustment                                         | 5          | Set Water Temperature Offset                                         | 22        |
| Multiple Unit Installation                                               | 6          | Defrost Cycle                                                        | 22        |
| Heat Pump, Heater, Solar Combination                                     | 6          | Run Time Counters                                                    | 22        |
| Multiple Heat Pump Connections                                           | 6          | Locking the Control Panel                                            | 22        |
| Electrical Connections and Wiring                                        | 8          | <b>Maintenance .....</b>                                             | <b>23</b> |
| Wiring Diagram – (Single Phase – 50/60 Hz)                               | 9          | Water Chemistry                                                      | 23        |
| Wiring Diagram – (Three Phase – 60 Hz)                                   | 10         | Winterizing                                                          | 23        |
| Wiring Diagram – (Three Phase – 50 Hz)                                   | 11         | Spring Start Up                                                      | 23        |
| <b>Connecting to an Automation System .....</b>                          | <b>12</b>  | Inspection and Service                                               | 23        |
| Remote Operation                                                         | 12         | Owner Inspection                                                     | 23        |
| Relay Remote Controls                                                    | 12         | Professional Maintenance and Service                                 | 24        |
| Connecting to IntelliTouch or EasyTouch via<br>Heat Pump Spade Terminals | 13         | <b>Technical Information .....</b>                                   | <b>25</b> |
| Connecting to IntelliTouch or EasyTouch via<br>RS-485 Connector          | 14         | Electrical Supply - Voltage Requirements                             | 25        |
| Pin Configuration for Heat Pump Control<br>Board to IntelliTouch         | 15         | Temperature Resistance Chart                                         | 25        |
| Connecting IntelliTouch or EasyTouch to the<br>Heat Pump                 | 15         | Ambient/Water Flow Table for Professional<br>Maintenance and Service | 26        |
|                                                                          |            | Heat Pump Pressure Drop                                              | 26        |
|                                                                          |            | <b>Troubleshooting .....</b>                                         | <b>27</b> |
|                                                                          |            | <b>Replacement Parts .....</b>                                       | <b>32</b> |
|                                                                          |            | Illustrated Parts View                                               | 32        |
|                                                                          |            | Parts List                                                           | 33        |

*For pool energy saving tips, refer to page 16, under "Operating the Heat Pump". For technical data, voltage requirements, or ambient/water flow information, refer to page 25 at the back of the manual.*

# IMPORTANT WARNING AND SAFETY INSTRUCTIONS



## Important Notice:

This guide provides installation and operation instructions for the UltraTemp® Heat Pump. Consult Pentair with any questions regarding this equipment.

**Attention Installer:** This guide contains important information about the installation, operation and safe use of this product. This information should be given to the owner and/or operator of this equipment after installation or left on or near the heat pump.

**Attention User:** This manual contains important information that will help you in operating and maintaining this heat pump. Please retain it for future reference.



**WARNING** Before installing this product, read and follow all warning notices and instructions which are included.

Failure to follow safety warnings and instructions can result in severe injury, death, or property damage. Call (800) 831-7133 for additional free copies of these instructions.

## Codes and Standards

UltraTemp heat pumps are listed by ETL as complying with the latest edition of the "UL Standard for Safety for Heating and Cooling Equipment", UL 1995 and CSA C22.2 No. 236.

All Pentair heat pumps must be installed in accordance with the local building and installation codes as per the utility or authority having jurisdiction. All local codes take precedence over national codes. In the absence of local codes, refer to the latest edition of the National Electric Code (NEC) in the United States and the Canadian Electric Code (CEC) in Canada for installation.



## RISK OF ELECTRICAL SHOCK OR ELECTROCUTION.

The electrical supply to this product must be installed by a licensed, certified electrician or qualified personnel in accordance with the National Electrical Code and all applicable local codes and ordinances. Improper installation will create an electrical hazard which could result in death or serious injury to pool or spa users, installers, or others due to electrical shock, and may also cause damage to property. Read and follow the specific instructions inside this guide.



**WARNING** Do not permit children to use this product.



**WARNING** For units intended for use in other than single-family dwellings, a clearly labeled emergency

switch shall be provided as part of the installation. The switch shall be readily accessible to the occupants and shall be installed at least 5 feet [1.52 m] away, adjacent to, and within sight of the unit.

## Consumer Information and Safety

The UltraTemp series of heat pumps are designed and manufactured to provide safe and reliable service when installed, operated and maintained according to the information in this manual and the installation codes referred to in later sections. Throughout the manual, safety warnings and cautions are identified by the "⚠" symbol. Be sure to read and comply with all of the warnings and cautions.



**WARNING** The U.S. Consumer Product Safety Commission warns that elevated water temperature can be hazardous. See below for water temperature guidelines before setting temperature.



**WARNING** The following "Safety Rules for Hot Tubs" recommended by the U.S. Consumer Product Safety Commission should be observed when using the spa.

1. Spa or hot tub water temperatures should never exceed 104° F. [40° C.]. A temperature of 100° F. [38° C.] is considered safe for a healthy adult. Special caution is suggested for young children. Prolonged immersion in hot water can induce hyperthermia.
2. Drinking of alcoholic beverages before or during spa or hot tub use can cause drowsiness which could lead to unconsciousness and subsequently result in drowning.
3. **Pregnant women beware!** Soaking in water above 100° F. [38° C.] can cause fetal damage during the first three months of pregnancy (which may result in the birth of a brain-damaged or deformed child). Pregnant women should stick to the 100° F. [38° C.] maximum rule.
4. Before entering the spa or hot tub, the user should check the water temperature with an accurate thermometer. Spa or hot tub thermostats may err in regulating water temperatures.
5. Persons with a medical history of heart disease, circulatory problems, diabetes or blood pressure problems should obtain their physician's advice before using spas or hot tubs.
6. Persons taking medication which induce drowsiness, such as tranquilizers, antihistamines or anticoagulants should not use spas or hot tubs.

Hyperthermia occurs when the internal temperature of the body reaches a level several degrees above normal body temperature of 98.6° F. [37° C.]. The symptoms of hyperthermia include: drowsiness, lethargy, dizziness, fainting, and an increase in the internal temperature of the body.

*The effects of hyperthermia include:*

1. Unawareness of impending danger.
2. Failure to perceive heat.
3. Failure to recognize the need to leave the spa.
4. Physical inability to exit the spa.
5. Fetal damage in pregnant women.
6. Unconsciousness resulting in danger of drowning.

## Warranty Information

Heat pumps are sold with a limited factory warranty. Details are specified on the warranty card. Make all warranty claims to an authorized Pentair dealer or directly to the factory. Claims must include the heat pump serial number and model (this information can be found on the rating plate), installation date, and name of the installer. Shipping costs are not included in the warranty coverage. This warranty does not cover damage caused by improper assembly, installation, operation, improper water chemistry balancing or other chemical abuse, or improper sanitation application, winterizing, field modification, or failure to earth bond and properly ground the unit. Any changes to the heat pump, evaporator, heat exchanger, wiring, or improper installation may void the warranty.

## General Specifications

### Installation Location Certified for use:

**OUTDOOR USE ONLY.** Failure to provide the proper clearances outlined on page 3 will lower the performance of the heat pump and void the warranty.

**Water Pipe/Heater Connection** — Plastic 2" PVC (Unions included)

### Flow Rate

Maximum 120 gpm [456 lpm] - If system flow rate exceeds 120 gpm, a bypass valve is required.

Minimum 30 gpm [110 lpm]


Maximum Working Water Pressure 50 psi

**For Electrical Supply and Voltage Requirements, refer to the table on page 25.**

## ULTRATEMP® MENU TREE QUICK START GUIDE

1. Push the ON/OFF button to turn the unit on, the green "ON" light should be lit.
2. Select either Pool or Spa mode. The default is Pool mode.
3. Adjust the temperature to the desired setting by pushing either the UP arrow or DOWN arrow.
4. Allow 5 minutes for compressor restart delay.

See pages 17-22 for details on the Operator and Service menu screens on the control panel.



\* Menu appears only if Heat and Cool mode is enabled at the factory.

\*\* Menu appears only if AutoSet or Extend is enabled in the Service menu.

\*\*\* Menu appears only if a delay is active.

\*\*\*\* Menu appears only if Defrost is enabled in the Service menu.

### † INPUT STATUS

WF = WATER FLOW SWITCH  
HP = HIGH REFRIGERANT PRESSURE SWITCH  
LP = LOW REFRIGERANT PRESSURE SWITCH  
PL = POOL REMOTE  
SP = SPA REMOTE

### †† OUTPUT STATUS

FAN - FAN  
COMP - COMPRESSOR  
PMP - FILTER PUMP  
REV - REVERSING VALVE

# BEFORE INSTALLING THE HEAT PUMP

## UltraTemp® Heat Pump Overview

Your Pentair heat pump will provide you with years of heated pool enjoyment. Heat pumps operate by taking heat from the surrounding air and transferring it into the water. The warmer the air and the more humidity in the air, the more latent heat is available for heating your pool. With a properly sized heat pump for your pool, the heat pump should raise your pool on average 1° F per hour depending on air temperature, humidity, and water temperature. The ideal or rated condition for the heat pump is 80° F air temperature, 80% relative humidity, and 80° F water temperature. As conditions decrease from 80/80/80, the heat pump performance will decrease slightly.

Heat Pumps are best utilized to maintain a set water temperature; they are not intended to provide instant or fast heating. It is not reasonable to expect a heat pump to perform like a gas heater which has a much higher BTU output and faster response. Additionally, gas heaters are not dependent on environmental conditions. Swimming pool heat pumps are very similar to home heating and air conditioning heat pumps and therefore should be treated similarly.

Proper operation and use of the heat pump is to set it at your desired temperature and leave it. Your heat pump will turn on and off automatically to maintain your desired temperature much like your home HVAC unit. To take advantage of the sun's energy, operate your heat pump during the heat of the day.

Your heat pump will still operate when the temperature drops at night, but the output will be decreased. It is acceptable to shut the heat pump off and not use it for extended periods of time. When you have a need to heat your pool, please plan accordingly since it may take the heat pump days to heat your pool back to your desired temperature, depending on your pool temperature and environmental conditions.

## Heat Pump Installation Requirements

Correct installation is required to assure safe operation. The requirements for Pentair heat pumps include the following:

- Dimensions for critical connections.
- Field assembly (if required).
- Appropriate site location and clearances (pages 2-3).
- Proper electrical wiring (pages 8-11).
- Adequate water flow (page ii).

This manual provides the information needed to meet these requirements. Review all application and installation procedures completely before continuing the installation.

## General Installation Information

1. Installation and service must be performed by a qualified installer or service agency, and must conform to all national, state, and local codes.
2. Heat pumps get electrical power from an external source and provide a dual electronic thermostat control system for pool/spa combinations or preheat convenience.
3. This heat pump is specifically designed for heating fresh water swimming pools and spas. Do not use it as a general service heater. Consult your dealer for the appropriate Pentair products for these applications.

## General Features

- Dual digital thermostats offer precise temperature control to maintain the desired separate water temperatures in pool/spa combinations without overheating or wasting energy.
- Long-life corrosion resistant composite plastic cabinet stands up to severe climates and pool chemicals.
- 100% pure titanium heat exchanger assures corrosion-free performance for extra long life.
- Self-diagnostic control panel monitors and troubleshoots heat pump operations to ensure safe, dependable operation.
- Autaset (time clock over-ride) feature monitors water temperature and turns the water circulation pump on and off as needed to maintain desired pool temperatures.
- Extend (time clock over-ride) feature monitors water temperature and turns the water circulation pump on and off as needed to prolong a heating cycle that has been interrupted.
- Automatic Defrost feature senses refrigerant temperature and prevents the heat pump from freezing, allowing the heat pump to operate at even lower temperatures.
- Compatible with all automated control packages. RS-485 communication compatible with IntelliTouch® and EasyTouch® Control Systems.
- Thermostatic expansion valve (TXV) controls refrigerant flow for optimum efficiency and BTU output over a wider operating range.
- Elevated base pan for positive drainage of condensation.
- 2-inch plumbing connections for easy installation.
- Separate isolated electrical compartment prevents internal corrosion, extends heater life.
- Highest efficiency available, meets or exceeds existing codes and standards.
- Adjustable timer allows the operator to set the heat pump to run for a predetermined time. Incremental by 10 minutes to a maximum of 99 hours.
- An extensive list of operational conditions, alarms and water temperatures are logged on the control board. This information is available for the user to track performance and troubleshoot issues.

# INSTALLATION AND LOCATION

## CAUTION

When pool equipment is located below the pool surface, a leak from any component can cause large scale water loss or flooding. Pentair Water Pool and Spa, Inc. cannot be responsible for such water loss or flooding which may cause damage to property or to the product. Avoid placing the heat pump in locations where it can cause damage by water or condensate leakage. If this is not possible, provide a suitable drain pan to catch and divert any leakage.

Only a qualified service person should install the UltraTemp® Heat Pump. Before installing this product, refer to the *Important Warning and Safety Instructions* on page ii.

### Materials Needed for Installation

The following items are needed and are to be supplied by the installer for all heat pump installations:

1. Plumbing connections (2-inch).
2. Level surface for proper drainage.
3. Suitable electrical supply line. See rating plate on unit for electrical specifications. A junction box is not needed at the heat pump; connections are made inside of the heat pump electrical compartment. Conduit may be attached directly to the heat pump jacket.
4. Electric cutout switch that will interrupt all power to the unit. This switch must be within line of sight of the heat pump. Check local codes for requirements.
5. Watertight conduit to run the electrical supply line.

### Equipment Pad

For proper drainage of condensation and rain water, place the heat pump on a flat slightly pitched surface, such as a concrete or fabricated slab (pad).

If possible, place the pad at the same level or slightly higher than the filter system equipment pad.

**Note:** Be sure that the pad is pitched not more than 1/4 in. per foot in any direction as needed for runoff.

### Drainage and Condensation

Condensation occurs from the evaporator coil while the unit is running, and drains at a steady rate (usually three to five gallons per hour), depending upon ambient air temperature and humidity. The more humid the ambient conditions, the more condensation will be produced.

The bottom of the unit acts as a tray to catch rainwater and condensation. Keep the drain holes, located on the bottom pan of the base of the unit, clear of debris.

### Roof Run-off

Make sure the heat pump is not located where large amounts of water may run-off from a roof into the unit.


Sharp sloping roofs without gutters will allow massive amounts of rain water, mixed with debris from the roof to be forced through the unit. A gutter or down spout may be needed to protect the heat pump.

### Lawn Sprinklers

**Avoid placing lawn sprinkler near the heater - they can spray water into the heater and void the warranty.** Be sure to direct any spraying water away from the heater. Note the wind direction to be sure water from sprinklers is not blown toward the heater. Sprinkler heads can produce high water pressure and spray at an angle, different from typical rain and humid weather. Also, sprinklers connected to a well water system can cause mineral build up on the evaporator coils and electronics. Salt water can also be an issue if located near the coast.

**Heat Pump Dimensions**

| MODELS                                        | DIMENSION "A"   |
|-----------------------------------------------|-----------------|
| 70, 90, 90I                                   | 33.5" (851 mm)  |
| 100I                                          | 41.5" (1054 mm) |
| 110, 120, 120C, 140C<br>120 H/C, 140, 140 H/C | 45.5" (1156 mm) |




## Location and Clearances

All criteria given in the following sections reflect minimum clearances. However, each installation must also be evaluated, taking into account the prevailing local conditions such as proximity and height of walls, and proximity to public access areas.

The UltraTemp® Heat Pump must be placed to provide clearances on all sides for maintenance and inspection.

1. At least 24 in. [610 mm] access must be available in the front and 12 in. [305 mm] on all the other sides of the heat pump for service and proper air flow. (Manufacturer's recommendation).

2. If the heat pump is to be installed under a cover or under a vertical overhang, the unit must have a minimum of five (5) feet [1.52 m] clearance from the top of the heat pump. (Manufacturer's recommendation).
3. Install a minimum of five (5) feet [1.52 m] from the inside wall of the pool or spa unless the heat pump is separated from the pool or spa by a five (5) foot [1.52 m] high solid fence or other permanent barrier. Canadian installations require a minimum of three (3) meters [9.84 ft] from pool water.
4. Install heat pump a minimum of 6 in. [153 mm] from the wall of the house.



Heat Pump Location and Clearances

## Anchor Clamp Installation

Installation of the anchor clamps is recommended in all installations. Installation of the anchor clamps is required in Florida (see Florida Building Code 301.13).


Anchor clamps hold the heat pump to the equipment pad in order to withstand high winds caused during extreme weather (i.e. hurricanes).

### To install the anchor clamps:

1. Be sure the heat pump is in its permanent location on the equipment pad.
2. Place the clamps at the base of the heat pump in the four (4) locations, shown in the image to the right.

**Note:** Bolts and bolt anchors are not included with the heat pump. The installer must provide 1/4" x 1-3/8" stainless steel anchor bolts and the appropriate size concrete anchor to mount the clamp to the equipment pad. Be sure to check local codes.


3. Fit the hook of each clamp over the lip on the base panel of the heat pump. The hook should fit between the lip of the base panel and the evaporator coil guard.



Anchor Clamp Installation

## Anchor Clamp Installation, Continued

4. Mark the position of the hole in each clamp on the equipment pad.
5. Use a masonry drill bit and drill a hole in the cement with a diameter as determined by the concrete anchor, at each of the marks on the equipment pad. The hole should be approximately 1½ in. deep.
6. Insert a bolt anchor into each of the holes. Be sure the anchors are set completely into the holes.
7. Position the anchor clamps so that the holes in the clamps are over the bolt anchors.  
Be sure that the clamp hooks are over the lip of the heat pump base.
8. Insert an anchor bolt through each clamp into the anchor and tighten to secure the clamp and heat pump to the equipment pad.



Anchor Clamp Installation

## Water Connections and Plumbing

The image below shows the standard plumbing layout with a single UltraTemp® Heat Pump unit. Follow the image from right to left for the standard plumbing sequence.

Arrangement of pool system components (other than the standard plumbing image below), and the location of the heat pump (above or below the pool water surface) can affect the operation of the heat pump's water pressure switch.

The pressure switch can be adjusted to accommodate this effect if the heat pump water connections are no more than six (6) feet [1.82 m] below the pool water surface.


See instructions for pressure switch adjustment on the next page. If the heat pump is installed outside of this range, an external pressure switch may need to be installed in the plumbing upstream of the heat pump.

**Note:** Be advised that when pool equipment is located below the pool surface a leak can result in large-scale water loss or flooding. Pentair is not responsible for such water loss or flooding or damage.

## Automatic Flow Control Valve

The inlet/outlet header of the heat pump comes equipped with an internal automatic flow control valve. The automatic flow control valve maintains the proper flow through the heat pump at rates up to 120 gpm (456 lpm). If the filter system flow rate is higher than 120 gpm (456 lpm), install a manual bypass valve, see image below.

**Note:** Be advised that if your circulation pump is over 2 HP or if the total flow exceeds 120 gpm (456 lpm), you will have to add an external bypass valve. Excess water flow will damage the heat exchanger.




Standard Plumbing Layout

## Water Connections to the Heat Pump

2 in. Quick Connect fittings have been installed on the water inlet and outlet connections. Filtered cool water is plumbed to the inlet, located on the right side of the UltraTemp® Heat Pump. Heated water flows through the outlet, located on the left side of the heat pump.

Plastic piping (PVC Schedule 40) should be connected to the heat pump. The unions, provided with the unit, accept 2 in. PVC pipe.



Heat Pump Water Connections

### CAUTION

Always be sure that flow requirements and pool water turnover rates can be maintained with the installation of additional heat pumps and plumbing restrictions.

## Water Pressure Switch Adjustment

The pressure switch is preset at the factory for activation at 1.5 psi [10 kPa]. This factory setting works for most basic installations. Only adjust the water pressure switch if the heat pump does not operate **when the proper flow is applied to unit** or if the heat pump does not shut off when the filter pump is off. Occasionally, unusual plumbing configurations or necessary restrictions in the plumbing may cause pressure sensing problems. In these rare situations, the plumbing system configuration may require adjustment of the water pressure switch.

Adjustment of the pressure switch may be necessary if any part of the filter system piping is 3 feet [0.91 m] or more above the top of the heat pump.

In general, if the heat pump is installed more than 6 feet [1.83 m] below the pool surface, an external water flow switch must be added to the plumbing system.

On some installations, the piping from the heat pump

### CAUTION

The water pressure switch should be adjusted to turn the heater off when the pump is off. Setting the switch to close at too low of a flow can damage the appliance. Adjust the switch to turn the heater off, not on.

to the pool is very short. The back pressure could be too low to trigger the pressure switch. If this happens, install a directional fitting or elbow where the return line enters the pool. This will increase back pressure for the heat pump to operate properly. Be sure to check that the system flow is above the minimum requirement of 30 gpm (110 lpm) after the directional fitting installation.

Be sure the pool filter is clean before making any pressure switch adjustment: A dirty filter will restrict the water flow and the pressure switch cannot be adjusted properly.

### To adjust the pressure switch:

**The following adjustment is for installations where the heat pump is *below* pool water level.**

1. Be sure that all valves in the system are set to allow water flow through the heat pump. Start the filter pump.
2. Set the heat pump temperature above the actual temperature to call for heat. Turn the heat Pump ON.
3. Once the heat pump is running, turn off the filter pump. The heat pump should turn off immediately.
4. If the heat pump continues to operate when the filter pump is off, then the water pressure switch needs to be adjusted.
5. Remove the heat pump's left front panel and remove remaining right front panel. The water pressure switch is located in the water plumbing in the lower right corner of the heat pump.
6. Slowly rotate the adjustment wheel on the water pressure switch in a clockwise direction until the "LOW WATER FLOW" Alarm shows on the LCD, the red SERVICE light turns ON, and the heat pump stops.
7. Check the setting of the water pressure switch by starting and stopping the filter pump and checking the control panel and operation of the heater between each flow change.
8. If the water pressure switch cannot be adjusted to accommodate the conditions listed above, an external flow switch must be added to the plumbing system to ensure that the heat pump will not operate without the proper flow through the heat exchanger.

**The following adjustment is for installations where the heat pump is *above* pool water level.**

1. Be sure that all valves in the system are set to allow water flow through the heat pump. Start the filter pump.
2. Set the heat pump temperature above the actual temperature to call for heat. Turn the heat pump ON.
3. If the LCD shows a "LOW WATER FLOW" Alarm and red SERVICE light is present then the water pressure switch needs to be adjusted.

## Water Pressure Switch Adjustment, Continued

4. Remove the UltraTemp® Heat Pump's left front panel and remove remaining right front panel. The water pressure switch is located in the water plumbing in the lower right corner of the heat pump.
5. Slowly rotate the adjustment wheel on the water pressure switch in a counterclockwise direction until the "LOW WATER FLOW" Alarm and red SERVICE light vanish, time delay countdown will start.
6. Once the heat pump is running, turn off the filter pump. The heat pump should turn off immediately.
7. If the heat pump continues to operate when the filter pump is off, turn the adjustment wheel on the water pressure switch in a clockwise direction until the "LOW WATER FLOW" Alarm shows on the LCD, the red SERVICE light turns ON, and the heat pump stops.
8. Check the setting of the water pressure switch by starting and stopping the filter pump and checking the control panel and operation of the heater between each flow change.
9. If the water pressure switch cannot be adjusted to accommodate the conditions listed above, an external flow switch must be added to the plumbing system to ensure that the heat pump will not operate without the proper flow through the heat exchanger.

## Multiple Unit Installation

### 1. Heat Pump, Heater and/or Solar Combination

In certain regions of the country it may be more economical to run a heat pump during the warmer months and a gas heater during the cooler months. In some situations it may be desirable to run the heat pump in the "Chiller" mode, if so equipped, during the hottest portion of the year and a heater during the cooler months. The Pentair heat pump may be used in conjunction with a gas or electric heater or any combination of heat sources including solar. All heat sources must be plumbed in series to work correctly and efficiently.


A recommended plumbing layout for a heat pump / heater / solar combination heating system for a pool / spa combination is shown below. Your system may not contain all of these components, but the basic plumbing will apply by eliminating the component in the illustration that is not a part of your system.

### 2. Multiple Heat Pump Connections

All plumbing on multiple heat pump installations must be done in parallel (see next page). An equal flow of water to each heat pump is important for optimum operation.


**Note:** It may be necessary to adjust the water pressure switch if a unit is installed below the water level. Refer back to page 5 for details on when and how to adjust the pressure switch.

**Each heat pump in a multiple unit installation allows a maximum flow rate of 100 gpm (380 lpm) and requires a minimum of 30 gpm (110 lpm).**




Multiple Unit Installation:  
Heater and/or Solar Combination

## Multiple Unit Installation



Two Heat Pump Plumbing Layout



Four Heat Pump Plumbing Layout

## Electrical Connections and Wiring

### **WARNING**

#### **RISK OF ELECTRICAL SHOCK OR ELECTROCUTION.**



This heat pump contains wiring that carries high voltage. Contact with these wires could result in death or serious injury to pool or spa users, installers, or others due to electrical shock, and may also cause damage to property. Always disconnect power circuit before connecting the heat pump.

### **CAUTION**

Label all wires prior to disconnection when servicing controls. Wiring errors can cause improper and dangerous operation. Verify proper operation after servicing.

## General Information

Wiring connections must be made exactly as shown in the wiring diagram found on the inside of the heat pump access panel; see the wiring diagrams on pages 9-11.

The UltraTemp® Heat Pump must include a definite means of grounding and bonding. There is a ground lug inside the heat pump electrical compartment and a bonding lug on the left side of the heat pump.

## Bonding

The National Electrical Code and most other codes require that all metallic components of a pool structure, including reinforcing steel, metal fittings, and above ground equipment be bonded together with a solid copper conductor not smaller than 8 AWG. For Canada, a 6 AWG or larger solid copper bonding conductor is required. The heat pump, along with pumps and other pool equipment must be connected to this bonding grid. A bonding lug is provided on the left side of the heat pump to ensure this requirement is met.

### **CAUTION**

This heater must be connected to a bonding grid with a solid copper wire not smaller in diameter than 8 ga. For Canadian installations a solid copper wire not smaller in diameter than 6 ga should be used.

## Main Power


Electrical wiring to the heat pump must be in accordance with the latest edition of the National Electric Code (NEC), ANSI/National Fire Protection Association (NFPA) 70 in the United States, and in Canada, the Canadian Electrical Code (CEC) C22.1, unless local code requirements indicate otherwise. All wiring must be done by a certified or qualified electrician.

The following is the procedure to wire the heat pump to the electrical source:

***Be sure the power to the circuit for the heat pump is turned off.***

1. Remove the front left panel of the heat pump cabinet, (you do not need to remove the star-head screw at the top left corner).
2. Remove the service panel to the heat pump electrical compartment. (Front left corner of unit)
3. Electrical supply lines must be run through watertight conduit. Run the wires and conduit from the power source and connect them to the conduit connection on the left side of the heat pump.
4. Connect the power leads to the bottom terminals on the main compressor contactor as shown in the wiring diagram.
5. Verify that all other contactor wires are secure, they may have loosened during shipment.
6. Connect the ground wire to the ground lug provided on the bottom of the electrical compartment.
7. Replace the service panel and reinstall screws to hold it in place.
8. Replace the front left panel.
9. Connect a copper bonding wire (8 AWG) (6 AWG in Canada) to the bonding lug on the left side of the heat pump.


# Wiring Diagram – (Single Phase – 50Hz/60Hz)



LABEL P/N 473073 REV. F


ENGLISH

## Wiring Diagram – (Three Phase – 60Hz)



LABEL P/N 474022 REV. D

## Wiring Diagram – (Three Phase – 50Hz)



※ Note: If red LED is on, swap any two phases.

LABEL P/N 474017 REV. C

ENGLISH

# CONNECTING TO AN AUTOMATION SYSTEM

## Remote Operation

The UltraTemp® Heat Pump may be connected to an automation system via the remote spade terminals on the back of the control board (see page 12-13) or via the RS-485 communication connector on the back of the control board (see page 14-15). Refer to the IntelliTouch® or EasyTouch® Control System installation and user's guide for more information.

**Note:** Remote connection via the RS-485 connector is only available on IntelliTouch and EasyTouch software version 1.11 or higher. All other automation packages must connect via the ¼ in. "Spade" terminals (spade terminals not supplied).

## Relay Remote Controls


Electrical wiring must be in accordance with the latest edition of the NEC (NFPA 70) in the United States and CEC (CSA 22.1) in Canada, unless local code requirements indicate otherwise.

**To connect remote control equipment to the heat pump, perform the following steps:**

1. Turn off the power to both the remote pool/spa control system and the heat pump.
2. Remove the front left panel of the heat pump cabinet, (you do not need to remove the star-head screw at the top left corner).
3. Remove the electrical service panel to the heat pump. Remove the 4 bezel retaining screws from above the electrical compartment and rotate the bezel downward. This will allow you to access the Remote terminals on the back of the heat pump control board for the remote control installation.

4. Run the wires from the pool/spa remote control system into the upper electrical compartment.
5. Connect the wiring from the pool/spa remote control system to the heat pump remote control terminals using ¼ in. "Spade" connectors as shown in the image below.
6. Rotate the bezel back upwards into position and reinstall the 4 retaining screws.
7. Replace the electrical service panel.
8. Replace the front left panel.
9. Restore power to the heat pump and the pool/spa remote control system.
10. Press the MENU SELECT button repeatedly to scroll to the Remote Mode screen. Toggle the selection by pressing one of the arrows until the screen displays "Relay".
11. Turn on the heat pump.

**Note:** Heat pump control board set points will be shown as "N/A" and will be functionally disabled.



¼ in. "Spade" connectors


## Connecting the Heat Pump to the IntelliTouch® or EasyTouch® Control System Load Center via the Heat Pump Spade Terminals

To connect the UltraTemp® Heat Pump cable to the Personality Board in the IntelliTouch or EasyTouch Load Center:

1. Turn off the main system power before making any connections.
2. Unlatch the front door spring latches, and open the front door of the IntelliTouch or EasyTouch Load Center.
3. Loosen the two retaining screws from the top of the control panel and lower the control panel down to access the Personality Board.
4. Run a UL approved conductor cable from the heat pump to the Load Center.
5. Route the cable up through the low voltage raceway located on the left of the Load Center to the Personality Board, see image below.
6. Insert the UltraTemp cable plug onto the gas heater terminal connector, located on the left side of the Personality Board.

7. If the heat pump is used in conjunction with a gas heater, use a 520403 Dual Heater Relay Kit. Plug the heat pump relay connector onto the SOLAR Terminal on the top center of the Personality Board. Follow the Dual Heater Relay Kit instructions for further set-up details. Be sure to install solar temperature sensor as per instructions.
8. Lift the control panel up into position and secure with the two screws.
9. Connect the cable from the IntelliTouch or EasyTouch Load Center to the heat pump remote control terminals using ¼ in. "Spade" connectors. Refer to previous page for wiring instructions.

**Note:** Solar temperature sensor could be left loose in load center. The automation system does not use the temperature reading but just looks for resistance.



IntelliTouch/EasyTouch Load Center Wiring Diagram

## Connecting the Heat Pump to the IntelliTouch® or EasyTouch® Control System Load Center via the RS-485 Connector



Switch the main power off to the IntelliTouch® or EasyTouch® load center before servicing.

The UltraTemp® Heat Pump can be controlled by an IntelliTouch or EasyTouch system via the RS-485 communication cable. In this configuration, IntelliTouch or EasyTouch overrides preset Temperature Set points on the heat pump.

The transfer of this data takes several seconds and causes a delay from when the command is given from the IntelliTouch or EasyTouch indoor control panel until the heat pump physically responds. This happens automatically but may take 1-2 minutes to complete.

**Note: Heat pump control board set points will be shown as “N/A” and will be functionality disabled. For more information, refer to the IntelliTouch User’s Guide (P/N 520102) or the EasyTouch User’s Guide (P/N 520584) or the EasyTouch Wireless System User’s Guide (P/N 520688).**



Connection from heat pump board to the IntelliTouch or EasyTouch system is via the optional four-wire cable (P/N 520199).

**To connect the heat pump board cable to the IntelliTouch or EasyTouch load center:**

1. Unlatch the IntelliTouch or EasyTouch load center front door spring latches, and open the front door.
2. Remove the cover-panel screws securing the high voltage cover-panel, and remove it from the enclosure.
3. Loosen the two control panel access screws and fold down the outdoor control panel.
4. Insert the four-wire cable into plastic grommet on the bottom of the enclosure and route the wire up through the low voltage raceway to the Personality board.
5. Strip back the cable conductors ¼ in. Insert the wires into either of the COM PORTS (J7 and J8) screw terminals located on the left side of the Personality board. Secure the wires with the screws. For wiring details, refer to the pin configuration as shown on page 15..

**Note: Multiple wires may be inserted into single screw terminal.**

6. Close the IntelliTouch control panel and secure it with the two access screws.
7. Install the high voltage panel cover and secure it with the two retaining screws.
8. Close the load center front door and secure with the two latches.
9. Switch power on to the IntelliTouch load center.




IntelliTouch Load Center

## Pin Configuration for the Heat Pump Control Board to IntelliTouch® Control System

1. Heat Pump Control Board: Connect pin 2 (green) to IntelliTouch screw terminal pin 2 (green).
2. Heat Pump Control Board: Connect pin 3 (yellow) to IntelliTouch screw terminal pin 3 (yellow)

**IMPORTANT** — Do **NOT** use pin 1 (black) or pin 4 (red) on the AutoSet board or the IntelliTouch mother board.



## Connecting the IntelliTouch or EasyTouch to Heat Pump

1. Turn off the power to both the remote pool/spa control system and the UltraTemp® Heat Pump.
2. Remove the front left panel of the heat pump cabinet, (you do not need to remove the star-head screw at the top left corner).
3. Remove the electrical service panel to the heat pump. Remove the 4 bezel retaining screws from above the electrical compartment and rotate the bezel downward. This will allow you to access the Remote terminals on the back of the heat pump control board for the remote control installation.
4. Run the wires from the pool/spa remote control system into the upper electrical compartment.
5. Connect the wiring from the IntelliTouch Personality Board COM PORT to the RS-485 IntelliTouch connection (J8) on the heat pump control Board. Connect the green wire to J8 pin 2 and yellow wire to J8 pin 3. Do NOT use pin 1 (red) or pin 4 (black) wires. The connections are shown in the image above.
6. Rotate the bezel back upwards into position and reinstall the 4 retaining screws.
7. Replace the electrical service panel.
8. Replace the front left panel.
9. Restore power to the heat pump and the pool/spa remote control system.
10. Press the MENU SELECT button to scroll to the Remote Mode screen. Toggle the selection by pressing one of the arrows until the screen displays "RS-485."
11. Once the heat pump has been correctly configured, a "heartbeat" indicator will appear on the main screen each time a message is received from the automation system.

POOL HEATING F ★ --- Heartbeat Indicator  
SET= N/A ACT= 74

**Note:** If the system is put into Service Mode at the automation control panel the heat pump will neither heat nor cool, although it will remain powered on.

# OPERATING THE HEAT PUMP

## CAUTION

Do not use this heat pump if any part has been under water. Immediately call a qualified service technician to inspect the heater and replace any part of the control system which has been under water. Keep all objects off the top of the heat pump. Blocking air flow could damage the unit and may void the warranty.

## ATTENTION - INITIAL START UP PRECAUTIONS

After the water pressure switch is activated there is a one minute temperature sensing delay then if there is a call for heat or cool the fan will turn on and there will be an additional 5 minute delay for the compressor to start. Be sure that there is water in the pool and that the surface level is above the skimmer or other inlets of the pool's filter system.

**The pool pump must be on and water flowing through the heat pump for it to operate.**

With any new pool or spa installation, operate the filter pump with the heat pump off long enough to completely clean the water. This will remove any installation residue from the water. Clean the filter at the end of this operation before starting the heat pump. When raising the temperature of a cold pool, program the time clock to run the pump continuously. This lets the filter system and heat pump operate continuously until the water reaches the temperature setting on the temperature control. When that happens, the heat pump will automatically shut off, but the filter pump will keep running.

## Swimming Pool Energy Saving Tips

It is important to note that an UltraTemp® Heat Pump will not heat a pool as fast as a large gas or electric pool heater. If the pool water is allowed to cool significantly, it may take several days to return to the desired swimming temperature.


For weekend use, it is more economical to maintain the water temperature at or near the desired temperature. For extended non-use, turn the heat pump completely off or decrease the temperature setting of the control several degrees to minimize energy consumption.

Pentair offers the following recommendations to help conserve energy and minimize the cost of operating your heat pump without sacrificing performance.

1. The American Red Cross recommends a maximum water temperature of 78° F [25° C]. Use an accurate pool thermometer. A difference of 4° F. [2° C] , between 78° F and 82° F [26° C and 28° C], will significantly increase energy consumption.
2. Carefully monitor the water temperature of your pool in the summertime. You can reduce heat pump usage due to warmer air temperatures.
3. During the winter or when on vacation for longer than a week, turn off the heat pump.
4. Find the proper setting on the heat pump temperature control and use the Keypad Lock function to discourage further adjustments.
5. Where possible, shelter the pool from prevailing winds with well-trimmed hedges or other landscaping, cabanas, or fencing.
6. Pentair recommends the use of a pool cover. Besides providing a valuable safety feature, a pool cover will reduce heat loss, conserve chemicals, and reduce the load on filter systems.


## Heat Pump Control Panel Overview

1. **ON/OFF** button – Turns the heat pump ON and OFF.
2. **MENU SELECT** button – Displays Operator Menu Screens; also used to scroll through these menus.
3. **POOL/SPA** button – If pressed once, the current heat, cool or auto mode will be displayed along with the active set point, pool or spa.  
Pressing again will toggle between the pool or spa set point screens. The operator can also toggle between the pool and spa set point by using the UP and DOWN arrows.
4. **UP and DOWN Arrow** buttons – The UP and DOWN arrows will raise or lower the temperature set point if pressed while the run screen is displayed. They are also used to scroll through the various parameter values on the Operator Menus and Service Menu screens.
5. **LCD SCREEN** – Displays water temperature, set point temperature and heat pump parameters.
6. **ON Light** – Shows the heat pump is on.
7. **SERVICE Light** – Lit if alarm condition exists.



## Operator Menu Tree Guide

(Press UP and DOWN Arrows Simultaneously)



\* Menu appears only if Heat and Cool mode is enabled at the factory.

\*\* Menu appears only if AutoSet or Extend is enabled in the Service menu.

\*\*\* Menu appears only if a delay is active.

\*\*\*\* Menu appears only if Defrost is enabled in the Service menu.

## Navigating the Operator Menu Screens

Press the MENU SELECT button to view each screen. While in the menu screens, if no activity is detected after 15 seconds, the main screen is displayed.

### 1. Pool and Spa Run Screens

Displays whether the heat pump is idle, heating or cooling and if the Pool or Spa set point is active. Displays the water temperature set point and the actual measured water temperature.

### \* 2. Heat or Cool Mode Selection Screen

This screen is only shown on Heat-and-Cool heat pumps. This screen allows the operator to switch the heat pump between Heat-only, Cool-only and Auto Heat/Cool modes.

### 3. Heat Pump Timer Screen

This feature is an adjustable timer to allow the heat pump to run (green light ON) for a predetermined amount of time and then turn OFF (green light OFF).

### 4. Remote Mode Screen

Allows the operator to select the Remote mode, Off, Relay or RS-485 (serial). In Remote mode, the heat pump is controlled by an automation controller. The local Pool and Spa set points are not active (displayed as "N/A") in these modes.

### \*\* 5. AutoSet On/Off Screen

This screen is only shown if the AutoSet mode is enabled in the Service Menu Tree; it allows the operator to turn the AutoSet mode On and Off. AutoSet mode energizes a contactor for one cycle and starts a remote filter pump which allows the heat pump to heat or cool the water as necessary.

### \*\* 6. Extend On/Off Screen

This screen is only shown if the Extend mode is enabled in the Service Menu Tree; it allows the operator to turn the Extend mode On and Off. Extend mode energizes a contactor for one cycle and starts a remote filter pump which allows the heat pump to heat or cool the water as necessary.

### \*\*\* 7. Time Delay Screen

If the heat pump is waiting on any restart, pump start, or sensing water temperature delays, this screen shows how much delay time is left.

### \*\*\*\* 8. Suction Temperature Screen

Shows the suction line temperature of the refrigerant. This screen appears if the Defrost is enabled.

### 9. Alarm Screen

Shows if an alarm condition is present. If no alarms are present the screen will display ALARM STATUS NONE. The control board has the ability to store a 30 Alarm history of previous alarms that have occurred. At the alarm status screen, press the DOWN arrow. The first alarm will be the most recent alarm that has occurred. Successive presses (up to 30) of the DOWN arrow will display the alarm history in the order of occurrence. The operator can scroll back up using the UP button. There is an option to erase the history.

### 10. Operation Mode Screen

Displays whether the heat pump is in Heat, Cool or Auto mode. It also displays whether the Pool or Spa set point is active. The active set point can be switched between Pool and Spa by using the UP and DOWN arrows.

## Using the Control Panel

### Starting and Stopping the Heat Pump

The UltraTemp® Heat Pump is started and stopped with the ON/OFF button.

1. Starting - With power supplied to the heat pump, press the ON/OFF button to start the heat pump. The ON light should be lit.
2. Stopping - Press the ON/OFF button to stop the heat pump; the ON light will turn off. The screen shown below will be displayed temporarily.

PENTAIR AQUATICS  
HEAT PUMP OFF

### Changing the Set Point (Temperature)

The control board has two independently adjustable temperature set points. One is for the pool temperature control and the other is for the spa temperature control. The active mode of operation (Pool or Spa) is defined as the "active" set point.

1. Press the MENU SELECT button repeatedly until the associated run screen is displayed. Press the UP or DOWN arrows to adjust the pool or spa temperature set point.  
SET= \_\_\_\_ - Set point  
ACT= \_\_\_\_ - Actual measured water temperature
2. The screen automatically returns to the active run screen after 15 seconds of keypad inactivity.

POOL  
IDLE/HEAT/COOL  
SET= \_\_\_\_ ACT= \_\_\_\_

### Heat, Cool, and Auto Modes

Certain models have the ability to both heat and cool. These heat pumps can be setup to operate in any one of three modes (Heat Only, Cool Only, or Auto Heat and Cool).

In Auto mode, the heat pump automatically switches between heat and cool based on whether the water temperature is below or above the active set point.

1. If the cooling option is available, press the MENU SELECT button repeatedly until the Heat/Cool/Auto screen displays.
2. Press the UP or DOWN arrows to scroll through the heat, cool and auto options. The last option shown on the display becomes active.

### Heat Pump Timer

This feature is an adjustable timer to allow the heat pump to run for a predetermined amount of time (green light ON) and then turn OFF (green light OFF).

During the selected time frame, the green light is ON and the heat pump functions in the normal mode of operation. When time expires the green light turns OFF and the heat pump turns off. Countdown time is in hours and minutes.

#### To activate the Heat Pump Timer:

1. Press MENU SELECT repeatedly until the Heat Pump Timer screen is displayed.
2. Press UP or DOWN arrows to set the amount of time (range of 10 minutes to 99 hours). Timer adjusts in increments of 10 minutes.  
If the heat pump is not already on, setting the timer will activate and start the heat pump.

3. The user can also change the time while it is active using the arrow buttons, but only if Relay or Serial Remote modes are OFF. Turning Remote mode ON disables the Heat Pump Timer at the control panel.
4. Any RS-485 communication received will reset the timer to zero. The RS-485 overrides the Heat Pump Timer operation.
5. The timer can be disabled by pressing the DOWN arrow and POOL/SPA buttons at the same time, or by pressing the ON/OFF button.

HEAT PUMP RUNTIME  
REMAINING = NONE

### Relay Remote

In Relay Remote operation, the heat pump is started and stopped by remote relays which are connected to the remote POOL, COMMON and SPA quick connect terminals on the back of the control board. When conductivity is provided between the POOL and COMMON terminals or the SPA and COMMON terminals, the heat pump will start. The local Set Points are ignored in Relay Remote operation. All other features and functions (except for the Heat Pump Timer) are still active. The heat pump will not heat above 104°F or cool below 45°F (40°C - 7.2°C).

#### To activate the Relay Remote Mode:

1. Press MENU SELECT repeatedly until the Remote Mode screen is displayed. Once displayed, press the UP or DOWN arrows to select RELAY. The last option shown on the display becomes active.
2. Press MENU SELECT repeatedly until the Heat/Cool/Auto Mode Screen is displayed. Press the UP or DOWN arrows to toggle between HEAT, COOL and AUTO. Select HEAT or COOL. AUTO is not a valid selection while the heat pump is in Relay Remote mode operation.

REMOTE MODE  
RELAY

### RS-485 Remote (Serial Cable)

See IntelliTouch® or EasyTouch® Control System Installation User's Guides for additional setup instructions.

In RS-485 Remote mode, the heat pump is started and stopped via a serial RS-485 communications link with a Pentair automation controller. This means the remote automation controls override the heat pump's local set point. The high and low temperature faults are still active; the heat pump will not heat above 104°F or cool below 45°F (40°C - 7.2°C).

**Note:** If the system is put into Service Mode at the automation control panel the heat pump will neither heat nor cool, although it will remain powered on.

#### To activate the RS-485 Remote mode:

1. Press MENU SELECT repeatedly until the Remote mode screen is displayed. Once displayed, press the UP or DOWN arrows to select RS-485.

REMOTE MODE  
RS-485

To use the RS-485 Remote mode, the Intell Address screen from the Service Menu Tree must be assigned to the proper address. One (1) is the most commonly used address.

The address on the Intell Address screen must match the address assigned to the heat pump. The heat pump address can be changed from the Service Menu as described below:

1. Press the UP and DOWN arrows simultaneously. The Language Selection screen should be displayed.

LANGUAGE/IDIOMA  
SELECTED - ENGLISH

2. Then press the MENU SELECT button repeatedly until the Intell Address screen is displayed. Once displayed, press the UP or DOWN arrows to select the address being used in the automation controller. The last address shown on the display will become active.

INTELL ADDRESS  
ADDRESS = 1-16

3. Once the heat pump has been correctly configured, a "heartbeat" indicator will appear on the main screen each time a message is received from the automation system.

POOL HEATING F  --- Heartbeat  
SET= N/A ACT= 74 Indicator

## AutoSet

The AutoSet feature periodically energizes a contactor which can be connected to activate the filter pump. The heat pump can now start and stop the filter pump independent of the time clock, allowing the heat pump to circulate water and sense water temperature. Enable this feature any time the filter pump is off.

If the temperature is not at the desired level, the heat pump starts and runs until the water reaches the desired temperature. The filter pump and the heat pump will stop when the water reaches the desired temperature.

AutoSet allows you to set the time interval between the end of the circulation cycle and when the heat pump reactivates the filter pump to sense the water temperature.

### To use this feature:

Be sure the water circulation pump is wired in parallel with a mechanical time clock, using the auxiliary relay supplied in the high voltage power panel of the heat pump.

### To enable the AutoSet feature:

1. Press the MENU SELECT button repeatedly until the AutoSet screen is displayed.
2. Press the UP or DOWN arrows to toggle between the ON and OFF options.
3. Set the interval (1-4 hours) from the Pump Start Time menu within the Service Menu tree to control when the heat pump sends a signal to check the water temperature.


*For example, if you select a Pump Start Time interval of four (4) hours, have the AutoSet feature enabled and have AutoSet Override set to ON, this is the sequence of events that will happen:*

1. The heat pump displays a countdown window after the filter pump shuts off.

PUMP START DELAY  
REMAINING 4:00

2. After four (4) hours, heat pump will switch on and start the filter pump to sense the water temperature.

3. If the pool temperature has fallen below your Set Point, the heat pump will turn on and begin heating the pool. If the pool temperature is above the Set Point, the heat pump and filter pump will shut off.
4. At the time the water circulation pump shuts off, the heat pump will reset and begin the countdown interval and display 'Pump Start Delay' again.
5. The heat pump will continue this cycle every time the water circulation pump is shut off.
6. Once the time clock turns on in the morning, the heat pump will stop the AutoSet feature and resume normal operation.



AutoSet Contactor to Mechanical Timer Wiring Example

### Notes:

1. Mechanical timer is not provided with the heat pump.
2. Example only, other timers will be similarly wired.
3. Be sure that the electrical power lines are not crossed when making connections.

## Extend

The Extend feature can energize a contactor which can be connected to activate the filter pump. This allows the heat pump to start and stop the filter pump independent of the time clock, allowing the heat pump to circulate water and sense water temperature.

If the temperature is not at the desired level, the heat pump starts and runs until the water reaches the desired temperature. The filter pump and heat pump will stop when the water reaches the desired temperature.

### To use this feature:

Be sure the water circulation pump is wired in parallel with the mechanical time clock and the auxiliary relay installed on the high voltage panel of the heat pump.

### To enable the Extend feature:

1. Press the MENU SELECT button repeatedly until the Extend screen is displayed.
2. Press the UP and DOWN arrows to toggle between the ON and OFF options.

*For example, if you have the Extend feature enabled and the Extend Override set to ON, this is the sequence of events that will happen:*

1. After the filter pump shuts off, the heat pump immediately senses the water temperature.
2. If the water temperature is below the Set Point the heat pump will start the filter pump and begin heating the pool. If the water temperature is above the Set Point the heat pump and filter pump will shut off.
3. Once the time clock restarts the filter pump, the heat pump will stop the Extend feature and resume normal operation.

## Timers And Delays

### 1. Water Sensing Timer

One (1) minute timer to allow water from the pool to reach the UltraTemp® Heat Pump before acquiring temperature. This timer initiates when water first begins to run from stopped or low water flow conditions or when the heat pump is turned ON. Countdown time is in Minutes and Seconds.

SENSING WATER TEMP  
REMAINING = 1:00

### 2. Restart Delay Timer

Five (5) minute timer is a protection feature for the heat pump's compressor. This extends the life of the compressor by not allowing it to cycle on and off rapidly, (i.e. adjusting set point up and down around actual temperature). Countdown time is in minutes and seconds.

RESTART DELAY  
REMAINING = 5:00

### 3. Defrost Delay Timer

Fifteen (15) minute timer where the Heat pump is in Defrost operation. Countdown time is in minutes and seconds. Refer to page 22 for more details on the defrost cycle.

DEFROST DELAY  
REMAINING = 15:00

### 4. Pump Start Delay

One to four (1-4) hour timer used in conjunction with the AutoSet feature. Counts down the time until the control board will energize the internal contactor in the heat pump. Countdown time is in hours and minutes. See AutoSet section for more details.

PUMP START DELAY  
REMAINING 4:00

### 5. Heat Pump Runtime Timer

This feature is an adjustable timer to allow the heat pump to run (green light ON) for a predetermined amount of time and then turn OFF (green light OFF). During the selected time frame the green light is ON and the heat pump will function in the normal mode of operation and/or the operator can change set points, functions, etc. The heat pump's green light will turn OFF and the heat pump will stay OFF when time expires.


HEAT PUMP RUNTIME  
REMAINING = NONE

## Control Panel Alarm Messages

|                          |                                                                                                                                                                           |
|--------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>HIGH WATER TEMP</b>   | Water temperature is above 107° F [41.7° C].                                                                                                                              |
| <b>LOW WATER TEMP</b>    | Water temperature is below 40° F [4.4° C].                                                                                                                                |
| <b>LOW WATER FLOW</b>    | The pressure switch sensing water flow is open.                                                                                                                           |
| <b>REMOTE POOL/SPA</b>   | Pool and Spa relay remote inputs are simultaneously energized.                                                                                                            |
| <b>WATER THERM SHORT</b> | Water temperature thermistor circuit shorted.                                                                                                                             |
| <b>WATER THERM OPEN</b>  | Water temperature thermistor circuit open.                                                                                                                                |
| <b>SUCTION TH SHORT</b>  | Defrost thermistor circuit shorted                                                                                                                                        |
| <b>SUCTION TH OPEN</b>   | Defrost thermistor circuit open.                                                                                                                                          |
| <b>BROWNOUT</b>          | The 24 VAC supply voltage to the control board is low.                                                                                                                    |
| <b>HIGH REFRIG</b>       | Refrigerant high pressure switch is open.                                                                                                                                 |
| <b>LOW REFRIG</b>        | Refrigerant low pressure switch is open.                                                                                                                                  |
| <b>SERIAL COMM LOST</b>  | Control board has not received a message from the automation controller for two (2) minutes.                                                                              |
| <b>FIVE ALARMS</b>       | Indicates that five (5) faults have occurred in one (1) hour. This fault will automatically reset in one (1) hour or can be manually reset by pressing the ON/OFF button. |

## Service Menu Tree Guide

(Press UP and DOWN Arrows Simultaneously)



\*\* Menu appears only if AutoSet or Extend is enabled in the Service menu.

### † INPUT STATUS

WF = WATER FLOW SWITCH  
HP = HIGH REFRIGERANT PRESSURE SWITCH  
LP = LOW REFRIGERANT PRESSURE SWITCH  
PL = POOL REMOTE  
SP = SPA REMOTE

### †† OUTPUT STATUS

FAN - FAN  
COMP - COMPRESSOR  
PMP - FILTER PUMP  
REV - REVERSING VALVE

The number one (1) is displayed when the associated input/output is ON and zero (0) is displayed when input/output is OFF.

## Navigating the Service Menu Screens

Press the UP and DOWN arrows simultaneously. If no activity is detected after 15 seconds, the display will return to the main screen.

### 1. Language Selection

Displays the language selected. Select either English, Spanish or French using the UP and DOWN arrows.

### 2. Software Revision

Displays the software revision level loaded on the control board.

### 3. Intell Address

Heat Pump RS-485 Communications Address which must match the address used in the IntelliTouch or EasyTouch automation controller being communicated with. Adjustable from 1 to 16 using the UP and DOWN arrows.

### \*\* 4. Pump Start Time

This displays the period at which the heat pump will close the AutoSet contactor to start the filter pump. Adjustable from 1 to 4 hours using the UP and DOWN arrows.

### 5. Pump Start Delay

Displays the time period between heat pump start cycles. Adjustable from 0 to 5 minutes using the UP and Down arrows.

### 6. Temperature Scale

Determines if the water temperature actual reading and set point is displayed in degrees Fahrenheit or Celsius. Adjusted between Fahrenheit and Celsius using the UP and DOWN arrows.

### 7. Temp Offset

Adjusts the measured water temperature up or down to allow the operator to match the heat pump's displayed temperature to a remote temperature monitoring device. The offset can be varied from -2 to +2 using the UP and DOWN arrows.

### 8. Defrost Screen

Allows the user to Enable/Disable Defrost feature.

### 9. AutoSet Screen

Allows the user to Enable/Disable AutoSet feature.

### 10. Extend Screen

Allows the user to Enable/Disable Extend feature.

### † 11. Input Screen and Output Screen

†† The Input and Output screens are diagnostic displays which show the status of the input sensors and output devices. The number one (1) is displayed when the associated input/output is on and zero (0) is displayed when the associated input/output is off.

### 12. Temperature Log and Run Time Counters

These screens display a list of compressor, fan and valve run times, and a history of measured water temperatures. This information is provided so the user can easily track performance and troubleshoot issues.

### 13. Exit Set Up

Pressing the POOL/SPA button while this screen is displayed returns the display to the Pool or Spa Run Screen as appropriate.

### Temperature Scale - C° or F°

The control board can display temperatures in either degrees Fahrenheit or Celsius. The temperature scale in use can be changed from the Service Menu tree as described below:

1. Press the UP and DOWN arrows simultaneously. The Language Selection screen should be displayed.
2. Then press the MENU SELECT button repeatedly until the Temperature Scale screen is displayed.
3. Press the UP or DOWN arrows to toggle between the Fahrenheit and Celsius options. The last option shown on the display will become active.

### Water Temperature Offset

The control board provides the ability to increase or decrease the displayed water temperature by 2 degrees.

To change the temperature offset:

1. Press the UP and DOWN arrows simultaneously.
2. Press the MENU SELECT button repeatedly until the Temperature Offset screen is displayed.
3. Press the UP or DOWN arrows to select the desired offset. The last number shown on the display will become active.

TEMP OFFSET  
OFFSET = -2 TO +2

### Defrost Cycle

The UltraTemp® Heat Pump may enter a defrost cycle if air temperatures are around 50°F (10°C). To enter a defrost cycle the Defrost feature must be enabled in the Service Menus.

### Passive Cycle

The passive defrost cycle initiates when the evaporator sensor detects refrigerant temperature below the defrost set point. At this time, the heat pump compressor stops. The heat pump evaporator fan will continue to run, and will draw air over the evaporator fins for about 15 minutes.

If the refrigerant sensor detects a temperature above the defrost stop temperature (start set point +20°F), the compressor will restart after the 15 minutes. If not, the unit will shut down.

**Note:** The efficiency of a heat pump decreases as air temperature decreases. For maximum efficiency, operate the heat pump during the warmest time of day.

### Run Time Counters

Details of the Run Time Counter abbreviations are listed below:

COMP = COMPRESSOR  
FAN = EVAPORATOR FAN  
REV VLV = REVERSING VALVE (COOLING CYCLE)  
FLT PMP = FILTER PUMP (AUTOSET/EXTEND FEATURE)  
DEFROST = DEFROST FEATURE

**RUN TIME** = total time of the current cycle

**LOG TIME** = accumulated time of all cycles since the last time the unit was powered on

**CYCLES** = number of cycles since the last time the unit was powered on

**WARRANTY HOURS** = accumulated time of all cycles over the lifespan of the unit

**WARRANTY CYCLES** = number of cycles over the lifespan of the unit


Press the UP and DOWN arrows to scroll through the Timers and Counters. The last screen provides an option to reset the Run Time, Log Time and Cycles counters. The Warranty Hours and Warranty Cycle Counter cannot be reset.

### Locking the Control Panel

1. Heat pump control panel lock-out – To prevent unwanted adjusting or manipulating of the heat pump settings, the control panel can be locked. Once locked, if any button is pressed, the display will read:

HEAT PUMP  
CONTROLS LOCKED

- To activate the control panel lockout, press the MENU SELECT and POOL/SPA buttons simultaneously.
- To unlock the control panel, press the MENU SELECT and POOL/SPA buttons simultaneously.



# MAINTENANCE

## Water Chemistry

Proper chemical balances are necessary for sanitary bathing conditions as well as ensuring your heat pump's long life.

Be sure to keep your chemical and mineral concentration levels within the values indicated in the table below. Failure to maintain proper water chemistry may cause damage to the UltraTemp® Heat Pump and may void the warranty.

Optimal Water Chemistry Ranges

| Test                                                                                                                   | Recommended Level               |
|------------------------------------------------------------------------------------------------------------------------|---------------------------------|
| Free Chlorine <i>or</i>                                                                                                | 1.0 to 3.0 ppm (3.0 to 5.0 spa) |
| Bromine                                                                                                                | 2.0 to 4.0 ppm (3.0 to 5.0 spa) |
| pH                                                                                                                     | 7.4 to 7.6                      |
| Total Alkalinity (TA)<br>Calcium, Lithium, and<br>Sodium Hydrochlorite                                                 | 80 to 100 ppm                   |
| Total Alkalinity (TA)<br>Sodium Dichlor, Trichlor,<br>Chlorine Gas, and<br>Bromine Compounds                           | 100-120 ppm                     |
| Calcium Hardness (CH)                                                                                                  | 200 to 400 ppm                  |
| Cyanuric Acid                                                                                                          | 30 to 50 ppm                    |
| Total Dissolved Solids (TDS)                                                                                           | Less than 2000 ppm              |
| Copper                                                                                                                 | 0 ppm                           |
| * Concentration levels taken from "Basic Pool and Spa Technology" published by NSPI (National Spa and Pool Institute). |                                 |

## Winterizing



Failure to winterize could cause damage to the heat pump and will void the warranty.

In areas where freezing temperatures occur, you should protect your pump, filter, and heat pump from the elements. Perform the following steps to completely drain the heat pump.

1. Turn off the electrical power to the heat pump at the main breaker panel.
2. Shut off the water supply to the heat pump.
3. Disconnect the water inlet and outlet unions located on the lower front panel of the heat pump.
4. Blow out the water lines.
5. Cover only the top of the heat pump to prevent debris from falling into the unit. Do not wrap the sides of the heat pump with any plastic or other material that will retain heat or moisture inside the unit.

## Spring Start Up

If your heat pump has been winterized, perform the following steps when starting the system in the Spring:

1. Uncover the heat pump and inspect the top and sides for any debris or structural problems.
2. Connect the water inlet and outlet unions on the sides of the heat pump.
3. Turn on the filter pump to supply water to the heat pump. Open the filter air bleeder and circulate water through the system long enough to bleed all the air out of the pool system. Check for leaks in and around the heat pump.
4. Turn on the electrical power to the heat pump at the main breaker panel.

## Inspection and Service

Pentair Heat Pumps are designed and constructed to provide long performance life when installed and operated properly under normal conditions.

Periodic inspections are important to keep your heat pump running safely and efficiently through the years. Failure to properly maintain your unit can void the warranty.

## Owner Inspection

Pentair recommends that you inspect your heat pump on a continual basis and especially after abnormal weather conditions. The following basic guidelines are suggested for your inspection:

1. Make sure the front of the unit is accessible for future service.
2. Keep the top and surrounding areas of the heat pump clear of all debris.
3. Keep all plants and shrubs trimmed and away from the heat pump.
4. Keep lawn sprinkler heads from spraying on the heat pump to prevent corrosion and damage.
5. If the unit is installed under a roof edge, install a gutter or diverter to prevent excessive water and debris from pouring down into the unit.
6. Do not use this heat pump if any part has been under water. Immediately call a qualified professional technician to inspect the heat pump and replace any part of the control system which has been submerged.

*Continue onto the next page for "Owner Inspection".*

## Owner Inspection, Continued

The UltraTemp® Heat Pump will produce condensation (water) while in operation. The heat pump base is designed to allow the condensation to exit through the bottom drain port when the unit is running. The condensation will increase as the outdoor air humidity level increases. Check the following at regular intervals to ensure proper condensate drainage:

1. Visually inspect and clear the bottom drain ports of any debris that could clog the ports.
2. Keep the top air flow discharge and air flow intake area clear of debris so the air flow through the heat pump is not restricted. The cooler discharge air from the top should not accumulate and be drawn into the side air intake coils.
3. Be sure the condensate run-off is properly directed away from the equipment pad to keep it from undermining the pad.
4. Be sure the condensate water does not puddle inside the heat pump. To be sure it is condensate water, check for the absence of chlorine.

During normal operation, the heat pump produces three to five gallons of condensate per hour. If condensate drainage is above this range during operation or if water continues to drain from the base when the heat pump is not in operation for more than an hour, a leak in the internal plumbing may have occurred. Call a qualified heat pump technician to investigate the problem.


## Professional Maintenance and Service

The maximum heat output and efficiency of a heat pump is dependent upon the quality and performance of the major components used. Equally important are the environmental conditions (for example, air temperature, humidity, water temperature, and wind).

To maintain maximum performance and efficiency, keep the air coil clean from dirt and debris. It is recommended to clean your air coil once a year by flushing the coil with compressed air or hosing off the coil with a garden hose.

Care should be taken to not bend the coil fins as this will restrict the airflow and lower your heat pump performance. Compressed air can also damage the heat pump coil. **DO NOT USE A PRESSURE CLEANER ON THE UNIT.**

The heat pump should be maintained at least once a year by qualified personnel to maintain maximum performance and efficiency. The unit should be powered off during maintenance.



Typical Heating Cycle

# TECHNICAL INFORMATION

## Electrical Supply - Voltage Requirements

| Models                             | UltraTemp®   |              |              |              |              |              |              |              |              |             |              |
|------------------------------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|--------------|
|                                    | 70           | 90           | 110          | 120          | 120 H/C      | 140          | 140 H/C      | 120C         | 140C         | 100I        | 90I          |
| Voltage/Phase/Hz                   | 208-230/1/60 | 208-230/1/60 | 208-230/1/60 | 208-230/1/60 | 208-230/1/60 | 208-230/3/60 | 208-230/1/60 | 208-230/3/60 | 208-230/3/60 | 230/1/50    | 380-400/3/50 |
| Min. Circuit Ampacity (Amp)        | 33           | 40           | 42           | 42           | 42           | 43           | 43           | 34           | 35           | 42          | 18           |
| Recommended Fuse Size              | 40           | 50           | 50           | 50           | 50           | 50           | 50           | 50           | 50           | 50          | 30           |
| Max Fuse Breaker Size              | 50           | 60           | 70           | 70           | 70           | 70           | 70           | 60           | 60           | 60          | 40           |
| Compressor/Fan Motor/System<br>RLA | 25/2/27      | 31/2/33      | 32/2/34      | 32/2/34      | 32/2/34      | 32/3/35      | 32/3/35      | 25/2/27      | 25/3/28      | 32/2/34     | 12/1/13      |
| Compressor/Fan Motor/System<br>LRA | 134/4/138    | 178/4/182    | 148/4/152    | 185/4/189    | 185/4/189    | 185/11/196   | 185/11/196   | 164/4/168    | 164/11/175   | 130/4/134   | 87/3/90      |
| Compressor/Fan Motor/System<br>MCC | 39/NA/NA     | 49/NA/NA     | 50/NA/NA     | 50/NA/NA     | 50/NA/NA     | 50/NA/NA     | 50/NA/NA     | 39/NA/NA     | 39/NA/NA     | 50/NA/NA    | 19/NA/NA     |
| Capacity (Btu/h) 80A-80RH-80W *    | 75,000       | 90,000       | 108,000      | 127,000      | 127,000      | 143,000      | 140,000      | 123,000      | 140,000      | 102,000     | 85,000       |
| COP 80A-80RH-80W *                 | 5.8          | 5.7          | 6.0          | 5.7          | 5.6          | 5.8          | 5.6          | 5.6          | 5.8          | 5.9         | 5.7          |
| Power Input, KW (80A-80RH-80W) *   | 3.8          | 4.6          | 5.3          | 6.5          | 6.6          | 7.2          | 7.3          | 6.4          | 7.1          | 5.1         | 4.4          |
| Current, Amp (80A-80RH-80W) *      | 18           | 21           | 26           | 30           | 31           | 33           | 34           | 18           | 23           | 25          | 9            |
| Capacity (Btu/h) 80A-63RH-80W **   | 70,000       | 84,000       | 101,000      | 120,000      | 120,000      | 134,000      | 132,000      | 115,000      | 132,000      | 96,000      | 81,000       |
| COP 80A-63RH-80W **                | 5.6          | 5.5          | 5.8          | 5.5          | 5.4          | 5.6          | 5.4          | 5.3          | 5.6          | 5.6         | 5.4          |
| Power Input, KW (80A-63RH-80W) *   | 3.6          | 4.5          | 5.1          | 6.4          | 6.5          | 7.0          | 7.2          | 6.4          | 6.9          | 5           | 4.4          |
| Current, Amp (80A-63RH-80W) *      | 17           | 20           | 25           | 29           | 30           | 32           | 33           | 18           | 22           | 24          | 9            |
| Capacity (Btu/h) 50A-63RH-80W ***  | 50,000       | 60,000       | 72,000       | 82,000       | 82,000       | 88,000       | 85,000       | 81,000       | 86,000       | 67,000      | 56,000       |
| COP 50A-63RH-80W ***               | 4            | 4            | 4            | 4            | 4            | 4            | 4            | 4            | 4            | 4           | 4            |
| Power Input, KW (50A-63RH-80W) *   | 3.6          | 4.4          | 5.3          | 6            | 6            | 6.4          | 6.2          | 5.9          | 6.3          | 4.9         | 4.1          |
| Current, Amp (50A-63RH-80W) *      | 17           | 19           | 24           | 27           | 28           | 29           | 29           | 17           | 21           | 24          | 9            |
| Shipping Weight (lbs) ****         | 250          | 250          | 270          | 270          | 278          | 320          | 320          | 280          | 320          | 280         | 250          |
| Shipping Size (L x W x H)          | 43"x34"x39"  | 43"x34"x39"  | 43"x34"x51"  | 43"x34"x51"  | 43"x34"x51"  | 43"x34"x46"  | 43"x34"x46"  | 43"x34"x51"  | 43"x34"x46"  | 43"x34"x47" | 43"x34"x39"  |

\* 80A-80RH-80W: 80° F Air Temp, 80% RH, 80° F Water Inlet Temp.

\*\* 80A-63RH-80W: 80° F Air Temp, 63% RH, 80° F Water Inlet Temp.

\*\*\* 50A-63RH-80W: 50° F Air Temp, 63% RH, 80° F Water Inlet Temp.

\*\*\*\* Add 50 lbs. for Pallet and Packaging.

COP = Coefficient of Performance

*If voltage drops below 208V, this may damage the heat pump and void the warranty. Take proper steps to ensure correct voltage at the heat pump during operation.*

## Temperature Resistance Chart

| *Temperature Resistance Chart |        |    |        |    |        |    |       |     |       |
|-------------------------------|--------|----|--------|----|--------|----|-------|-----|-------|
| °F                            | OHMS   | °F | OHMS   | °F | OHMS   | °F | OHMS  | °F  | OHMS  |
| 0                             | 85,387 | 51 | 19,377 | 66 | 13,136 | 81 | 9,076 | 96  | 6,382 |
| 10                            | 62,479 | 52 | 18,870 | 67 | 12,809 | 82 | 8,861 | 97  | 6,238 |
| 20                            | 46,225 | 53 | 18,377 | 68 | 12,491 | 83 | 8,651 | 98  | 6,097 |
| 30                            | 34,561 | 54 | 17,899 | 69 | 12,182 | 84 | 8,447 | 99  | 5,960 |
| 40                            | 26,100 | 55 | 17,435 | 70 | 11,882 | 85 | 8,249 | 100 | 5,827 |
| 41                            | 25,391 | 56 | 16,985 | 71 | 11,589 | 86 | 8,056 | 101 | 5,697 |
| 42                            | 24,704 | 57 | 16,548 | 72 | 11,305 | 87 | 7,867 | 102 | 5,570 |
| 43                            | 24,037 | 58 | 16,123 | 73 | 11,029 | 88 | 7,684 | 103 | 5,446 |
| 44                            | 23,391 | 59 | 15,711 | 74 | 10,761 | 89 | 7,506 | 104 | 5,326 |
| 45                            | 22,764 | 60 | 15,310 | 75 | 10,500 | 90 | 7,333 | 105 | 5,208 |
| 46                            | 22,156 | 61 | 14,921 | 76 | 10,246 | 91 | 7,164 | 106 | 5,094 |
| 47                            | 21,566 | 62 | 14,543 | 77 | 9,999  | 92 | 6,999 | 107 | 4,982 |
| 48                            | 20,993 | 63 | 14,176 | 78 | 9,758  | 93 | 6,839 | 108 | 4,873 |
| 49                            | 20,438 | 64 | 13,820 | 79 | 9,525  | 94 | 6,683 | 110 | 4,664 |
| 50                            | 19,900 | 65 | 13,473 | 80 | 9,297  | 95 | 6,530 | 120 | 3,758 |

The table below should be used by trained air-conditioning and refrigeration service people.

The table below **should not be used for adjusting the charge in the system.**

Use of interpolation or extrapolation of the table data may not be appropriate unless it is closely matched by the ambient and water flow conditions.

| Air: 80F, 80%RH   |                           | Water: 80F, 45-50gpm    |               |
|-------------------|---------------------------|-------------------------|---------------|
| Model             | Discharge Pressure (psig) | Suction Pressure (psig) | Superheat (F) |
| HP500             | 359                       | 134                     | 14            |
| HP700             | 348                       | 132                     | 14            |
| HP900             | 355                       | 142                     | 10            |
| HP1200            | 367                       | 141                     | 8             |
| HP1200R           | 367                       | 141                     | 8             |
| UltraTemp 70      | 329                       | 156                     | 19            |
| UltraTemp 90      | 340                       | 147                     | 20            |
| UltraTemp 110     | 343                       | 164                     | 11            |
| UltraTemp 120     | 350                       | 157                     | 9             |
| UltraTemp 120 H/C | 378                       | 157                     | 10            |
| UltraTemp 140     | 352                       | 168                     | 12            |
| UltraTemp 140 H/C | 377                       | 170                     | 10            |
| UltraTemp 120C    | 354                       | 150                     | 12            |
| UltraTemp 140C    | 365                       | 168                     | 13            |
| UltraTemp 100I    | 340                       | 154                     | 10            |
| UltraTemp 90I     | 354                       | 157                     | 9             |


| Air: 80F, 63%RH   |                           | Water: 80F, 45-50gpm    |               |
|-------------------|---------------------------|-------------------------|---------------|
| Model             | Discharge Pressure (psig) | Suction Pressure (psig) | Superheat (F) |
| HP500             | 352                       | 125                     | 11            |
| HP700             | 341                       | 123                     | 11            |
| HP900             | 348                       | 132                     | 8             |
| HP1200            | 360                       | 131                     | 6             |
| HP1200R           | 360                       | 131                     | 6             |
| UltraTemp 70      | 323                       | 149                     | 17            |
| UltraTemp 90      | 330                       | 138                     | 18            |
| UltraTemp 110     | 337                       | 153                     | 9             |
| UltraTemp 120     | 344                       | 146                     | 7             |
| UltraTemp 120 H/C | 368                       | 146                     | 8             |
| UltraTemp 140     | 345                       | 158                     | 10            |
| UltraTemp 140 H/C | 369                       | 158                     | 10            |
| UltraTemp 120C    | 346                       | 146                     | 10            |
| UltraTemp 140C    | 358                       | 160                     | 11            |
| UltraTemp 100I    | 335                       | 144                     | 8             |
| UltraTemp 90I     | 335                       | 152                     | 8             |

| Air: 50F, 63%RH   |                           | Water: 80F, 45-50gpm    |               |
|-------------------|---------------------------|-------------------------|---------------|
| Model             | Discharge Pressure (psig) | Suction Pressure (psig) | Superheat (F) |
| HP500             | 330                       | 83                      | 5             |
| HP700             | 320                       | 81                      | 4             |
| HP900             | 325                       | 85                      | 4             |
| HP1200            | 322                       | 86                      | 3             |
| HP1200R           | 322                       | 86                      | 3             |
| UltraTemp 70      | 313                       | 97                      | 7             |
| UltraTemp 90      | 312                       | 93                      | 4             |
| UltraTemp 110     | 324                       | 92                      | 4             |
| UltraTemp 120     | 330                       | 90                      | 3             |
| UltraTemp 120 H/C | 336                       | 90                      | 3             |
| UltraTemp 140     | 325                       | 98                      | 3             |
| UltraTemp 140 H/C | 327                       | 100                     | 3             |
| UltraTemp 120C    | 318                       | 89                      | 4             |
| UltraTemp 140C    | 320                       | 97                      | 4             |
| UltraTemp 100I    | 329                       | 86                      | 4             |
| UltraTemp 90I     | 327                       | 90                      | 4             |

| Air: 80F, 63%RH   |                           | Water: 104F, 45-50gpm   |               |
|-------------------|---------------------------|-------------------------|---------------|
| Model             | Discharge Pressure (psig) | Suction Pressure (psig) | Superheat (F) |
| HP500             | 457                       | 137                     | 7             |
| HP700             | 445                       | 142                     | 8             |
| HP900             | 450                       | 141                     | 5             |
| HP1200            | 478                       | 135                     | 6             |
| HP1200R           | 478                       | 135                     | 6             |
| UltraTemp 70      | 430                       | 164                     | 11            |
| UltraTemp 90      | 440                       | 152                     | 8             |
| UltraTemp 110     | 453                       | 159                     | 5             |
| UltraTemp 120     | 450                       | 152                     | 4             |
| UltraTemp 120 H/C | 474                       | 152                     | 4             |
| UltraTemp 140     | 461                       | 163                     | 8             |
| UltraTemp 140 H/C | 465                       | 165                     | 6             |
| UltraTemp 120C    | 450                       | 150                     | 7             |
| UltraTemp 140C    | 463                       | 165                     | 8             |
| UltraTemp 100I    | 452                       | 151                     | 4             |
| UltraTemp 90I     | 473                       | 150                     | 6             |

RH = Relative Humidity



# TROUBLESHOOTING



## RISK OF ELECTRICAL SHOCK OR ELECTROCUTION.

Improper installation will create an electrical hazard which could result in death or serious injury to pool users, installers, or others due to electrical shock, and may also cause damage to property. Do NOT attempt any internal adjustments inside the heater.



1. Keep your hands and hair clear of the fan blades to avoid injury.
2. If you are not familiar with your pool filtering system and heater:
  - a. Do NOT attempt to adjust or service without consulting your dealer, professional pool or air conditioning contractor.
  - b. Read the entire Installation & User's Guide before attempting to use, service or adjust the heater or pool filtering system. The water pressure switch should be adjusted to turn the heater off when the pump is off. Setting the switch to close at too low of a flow can damage the appliance. Adjust the switch to turn the heater off, not on.

**Always turn power to the unit OFF before servicing or repair.**

**Note:** Any service must be done by an authorized service agency person.

| Problem or Symptoms                                                                                                                                                                                                               | Possible Cause                                                                                   | Corrective Action                                                                                                                                                                                                                                                                          |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>HIGH WATER TEMP Alarm:</b><br>Water temperature above 107° F [41.7° C].                                                                                                                                                        | Bad Thermistor or bad control board.                                                             | Test water temp to see if it is correct, if not, use the 10k ohm resistance test to verify thermistor. If bad, replace thermistor. If good, replace control board. ★                                                                                                                       |
| <b>LOW WATER TEMP Alarm:</b><br>Water temperature below 40° F [4.4° C].                                                                                                                                                           | Bad Thermistor or bad control board.<br><br>Debris is shorting the connections.                  | Test water temp to see if it is correct, if not, use the 10k ohm resistance test to verify thermistor. If bad, replace thermistor. If good, replace control board. ★<br><br>Remove debris or replace PCB.                                                                                  |
| <b>LOW WATER FLOW Alarm:</b> The pressure switch sensing water flow is open.                                                                                                                                                      | 1. Water circulation pump not on.                                                                | Verify water circulation pump is on.                                                                                                                                                                                                                                                       |
|                                                                                                                                                                                                                                   | 2. Insufficient water flow.                                                                      | Dirty or worn filters or clogged lint traps. Verify filter is clean, backwash if necessary to clean entire filter system or replace filter element if needed. Inspect & clean pump impeller. Adjust Plumbing valves. Repair suction air leaks.                                             |
|                                                                                                                                                                                                                                   | 3. External bypass open.                                                                         | Make sure external water bypass around heat pump is closed.                                                                                                                                                                                                                                |
|                                                                                                                                                                                                                                   | 4. Bad water pressure switch.                                                                    | With water flowing, check resistance of water pressure switch, if open, replace switch.                                                                                                                                                                                                    |
| <b>REMOTE POOL SPA Alarm:</b><br>Pool and Spa remote inputs are simultaneously energized.                                                                                                                                         | Remote pool, spa, and common spade terminals on the back of the control board are all energized. | Modify automation control output so that only either the pool and common or spa and common terminals are energized.                                                                                                                                                                        |
| <b>WATER THERM SHORT Alarm:</b><br>Water temperature sensor circuit is shorted.                                                                                                                                                   | Bad Thermistor or bad control board.                                                             | Use the 10k ohm resistance test to verify thermistor. If shows shorted, replace thermistor. If good, replace control board. ★                                                                                                                                                              |
| <b>WATER THERM OPEN Alarm:</b><br>Water temperature sensor circuit is open.                                                                                                                                                       | Bad Thermistor, or bad control board.                                                            | Use the 10k ohm resistance test to verify thermistor. If shows open, replace thermistor. If good, replace control board. ★                                                                                                                                                                 |
| <b>SUCTION TH SHORT Alarm:</b> Defrost refrigerant temperature sensor circuit is shorted.                                                                                                                                         | Bad Thermistor or bad control board.                                                             | Use the 10k ohm resistance test to verify thermistor. If shows shorted, replace thermistor. If good, replace control board. ★                                                                                                                                                              |
| <b>SUCTION TH OPEN Alarm:</b> Defrost refrigerant temperature sensor circuit is open.                                                                                                                                             | Bad Thermistor or bad control board.                                                             | Use the 10k ohm resistance test to verify thermistor. If shows an open, replace thermistor. If good, replace control board. ★                                                                                                                                                              |
| <b>BROWNOUT Alarm:</b> The 24 VAC supply voltage to the control board is low.<br><br>CAUTION: High Voltage Checks. Observe extreme caution or call dealer or factory for advice before attempting to Troubleshoot Electrical Box. | 1. Bad transformer                                                                               | Supply voltage to the transformer should be between 208 and 260 volts. Transformer should output between 24 and 28 volts. If below this range, replace transformer.                                                                                                                        |
|                                                                                                                                                                                                                                   | 2. Insufficient supply voltage to the heat pump.                                                 | Check supply voltage to the heat pump. Supply voltage should be between 208 and 260 volts. Check to see if a phase is out. Should have 120 volts to ground and 240 volts across power legs. A boost transformer may be needed closer to the heat pump to get voltages within proper range. |

★ Refer to 10K Ohm Temperature Resistance Chart on page 25.

| Problems or Symptoms                                                                                                                                                    | Possible Cause                                                                                                                                                                                                                                                                                                                                                                                  | Corrective Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>HIGH REFRIG Alarm:</b> Refrigerant high pressure switch is open.                                                                                                     | 1. Water circulation pump not on.                                                                                                                                                                                                                                                                                                                                                               | Verify water pump is on.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|                                                                                                                                                                         | 2. Insufficient water flow.                                                                                                                                                                                                                                                                                                                                                                     | Verify filter and skimmers are clean, backwash if necessary. Minimum flow 30 GPM [113.6 LPM].                                                                                                                                                                                                                                                                                                                                                                                                                |
|                                                                                                                                                                         | 3. External bypass open.                                                                                                                                                                                                                                                                                                                                                                        | Verify external water bypass around heat pump is closed. Also make sure all other valves are open or in the proper positions to allow proper water flow through heat pump.                                                                                                                                                                                                                                                                                                                                   |
|                                                                                                                                                                         | 4. Bad refrigerant high pressure switch.                                                                                                                                                                                                                                                                                                                                                        | Check resistance of switch, if open, replace switch.                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
|                                                                                                                                                                         | 5. TXV Stuck Closed.                                                                                                                                                                                                                                                                                                                                                                            | 1. Disconnect TXV bulb from suction line (SL), have it in your hand, if pressures go back to normal, then reinstall the bulb on suction line (it may have some debris stuck in the port). For adjustable TXVs open adjustable valve, it may remove the debris and set it back to original position.<br>2. If (1) does not work, recover the charge, remove bulb from SL, unscrew TXV head, shake it, if rattles, replace head (PN KT-45-ZGA), if not, replace TXV and filter dryer and charge appropriately. |
|                                                                                                                                                                         | 6. Other Possibilities:                                                                                                                                                                                                                                                                                                                                                                         | Check Water level in pool. This condition may appear if the heat pump has NOT been operated for an extended period. To Clear this condition, cycle the heat pump on and off up to 3 times. If this does not correct problem, call for service.                                                                                                                                                                                                                                                               |
|                                                                                                                                                                         | 7. Other Possibilities. Low or restricted water flow through heater. Dirty or worn filters or clogged lint traps. Clogged filter pump impeller. Improper plumbing valve settings. Suction leak allowing air into the water flow. Low water flow when switched to spa mode. Unit is plumbed backwards. Heat exchanger clogged with debris. Internal bypass valve damaged or clogged with debris. | Clean entire filtering system and or replace filter element. Inspect & clean pump impeller. Adjust all plumbing valves. Repair suction air leaks, grease pump lid O-ring. Replace filter. Wrong filter pump pipe size. Automatic pool vacuum causing restriction. Call your dealer or factory for advice if above does not solve the problem.                                                                                                                                                                |
| <b>LOW REFRIG Alarm:</b> Refrigerant low pressure switch is open.                                                                                                       | 8. Unit overcharged.                                                                                                                                                                                                                                                                                                                                                                            | Reclaim charge. Recharge with appropriate nameplate charge.                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|                                                                                                                                                                         | 1. Low refrigerant in system.                                                                                                                                                                                                                                                                                                                                                                   | Find source of refrigerant leak and fix. Pull vacuum and recharge.                                                                                                                                                                                                                                                                                                                                                                                                                                           |
|                                                                                                                                                                         | 2. Air and water temperatures too cold to operate the heat pump.                                                                                                                                                                                                                                                                                                                                | Wait until temperatures warm up and see if unit operates.                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|                                                                                                                                                                         | 3. Bad refrigerant low pressure switch.                                                                                                                                                                                                                                                                                                                                                         | Check resistance of switch with a full charge, if open, replace switch.                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|                                                                                                                                                                         | 4. Faulty fan.                                                                                                                                                                                                                                                                                                                                                                                  | Check the capacitor and fan motor. Replace either one if it is faulty. Check the fan blade and make sure it is not slipping or broken. If so, replace the fan.                                                                                                                                                                                                                                                                                                                                               |
|                                                                                                                                                                         | 5. TXV Stuck Closed.                                                                                                                                                                                                                                                                                                                                                                            | 1. Disconnect TXV bulb from suction line (SL), have it in your hand, if pressures go back to normal, then reinstall the bulb on suction line (it may have some debris stuck in the port). For adjustable TXVs open adjustable valve, it may remove the debris and set it back to original position.<br>2. If (1) does not work, recover the charge, remove bulb from SL, unscrew TXV head, shake it, if rattles, replace head (PN KT-45-ZGA), if not, replace TXV and filter dryer and charge appropriately. |
| <b>FIVE ALARMS:</b> Indicates 5 faults have occurred in 1 hour. This fault will automatically reset in one hour or can be manually reset by pressing the ON/OFF button. | 6. Insufficient airflow through air coil                                                                                                                                                                                                                                                                                                                                                        | Remove surrounding debris or shrubs or heat pump maintenance by qualified personnel.                                                                                                                                                                                                                                                                                                                                                                                                                         |
|                                                                                                                                                                         | 5 alarms of any kind within one hour.                                                                                                                                                                                                                                                                                                                                                           | Press the ON/OFF button to clear the alarm. Check Heat Pump over the next few minutes/hours to see if alarm appears again. This alarm most likely caused the five alarms in one hour.                                                                                                                                                                                                                                                                                                                        |

| Problem or Symptoms                                                                                                                                                                              | Possible Cause                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | Corrective Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Unable to turn Heat Pump ON. Display is Blank. Unit will NOT start.                                                                                                                              | Control failure. No power supply to heater. Tripped breaker or blown fuse. Faulty Transformer. Incorrect Wiring.                                                                                                                                                                                                                                                                                                                                                                                                                                                             | Reset breaker. Replace fuse. Call dealer or factory for advice before attempting to replace parts. Replace Transformer. Check wiring.                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Unit power is ON, green light ON, and Set Temperature is above Actual. Unit will NOT start to heat or cool. No Alarms.                                                                           | Remote feature enabled, but no controlling device hook-up. Control failure.<br>Heat pump not turned on.                                                                                                                                                                                                                                                                                                                                                                                                                                                                      | Check to see if the Remote feature on the Control Board is enable. Disable if needed. See Section 3 for more information on disabling Remote function. Call dealer or factory for advice before attempting to replace parts. Replace Control Board.                                                                                                                                                                                                                                                                                                                                                     |
| Unit power is ON, green light ON, and Set Temperature is above Actual. Unit will NOT start to heat. No Alarms.                                                                                   | Heat Pump pool/spa selection mode incorrect. The thermostat is malfunctioning. Control Board Failure.                                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Check to see if heat pump is in correct active pool/spa mode by pressing the pool/spa button. If active mode is spa, but trying to heat/cool pool press pool/spa button again to change the active mode to pool. If active mode is Pool, but want spa heat change active mode to spa. Call dealer or factory for advice before attempting to replace parts. Replace thermostat. Replace Control Board.                                                                                                                                                                                                  |
| Unit power is ON, green light ON, and Set Temperature is above Actual. Unit cycles on and off, i.e. Compressor cuts on briefly and then off after Five minute delay before set point is reached. | Faulty Compressor. Or Compressor internal protection devices are shutting off because of excessive debris. Faulty Compressor contactor. Incorrect wiring. Control Board Failure. Internal bypass valve damaged or clogged with debris. Heat exchanger clogged with debris. Suction leak allowing air into the water flow. Unit is plumbed backwards.                                                                                                                                                                                                                         | Clean entire filtering system and or replace filter element. Inspect & clean pump impeller. Adjust all plumbing valves. Repair suction air leaks, grease pump lid O-ring. Replace filter. Wrong filter pump pipe size. Automatic pool vacuum causing restriction. Call your dealer or factory for advice if corrective action does not solve the problem. Possible Compressor's internal relief valve or overload protection device is faulty. Call dealer or factory for advice before attempting to replace parts. Replace Compressor.                                                                |
| Unit is forming ICE or Frost on the outer air coil, usually at the bottom.                                                                                                                       | Discharge air flow is restricted. Discharge air is accumulating and being drawn back through the outer air coil. The fan is obstructed, low air flow. Sprinklers spraying on the outer air coil during cooler temperatures. Outer air coil clogged with debris. Plants too close to heater, blocking discharge air flow. Low refrigerant pressure caused by a Refrigerant leak. Possible malfunctioning of the internal low refrigerant pressure switch. Check Alarm Status on Control Board for LOW REFRIG Alarm.                                                           | The outside air temperature too low and Defrost feature is NOT enable. Malfunctioning Defrost Thermistor. Make sure heater is installed with the required placement clearances for air flow and roof clearance. Do NOT install indoors. Make sure that your sprinklers do NOT spray on the heater in any way what so ever. If ice forms on the outer coil, shut the heater off and allow ice to thaw. You may use water at low pressure to thaw ice build up on the outer coil, shut the heater off when doing so. Call your dealer or factory for advice corrective action does not solve the problem. |
| Unit power is ON, and Set Temperature is above Actual. Fan is NOT Turning. No Alarms.                                                                                                            | Faulty Fan Relay. Faulty Capacitor. Faulty Fan Motor. Control Board Failure. Incorrect wiring.                                                                                                                                                                                                                                                                                                                                                                                                                                                                               | Call dealer for advice before attempting to replace parts. Replace Fan relay. Replace Capacitor, Replace Fan motor. Replace Control Board.                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| Fan is turning, no cool air discharge out of top of heater. Unit ON, and Set Temperature is above Actual, but Unit is not heating. No Alarms.                                                    | Heat Pump is in the five minute safety delay and Compressor has not started. Faulty Compressor. Faulty Capacitor. Compressor contactor is stuck open. Control Board failure. Incorrect wiring.                                                                                                                                                                                                                                                                                                                                                                               | Call dealer or factory for advice before attempting to replace parts. Replace Capacitor. Replace Control board. Replace Contactor. Replace Compressor.                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| "Spa will not heat to maximum temperature of 104° F.<br>Thermostat is turned all the way up.<br>OR<br>Spa is heating very slowly."                                                               | Low or restricted water flow through heater. Dirty or worn filters or clogged lint traps. Clogged filter pump impeller. Improper plumbing valve settings. Suction leak allowing air into the water flow. Low water flow when switched to spa mode or the control is not in spa mode. Unit is plumbed backwards. Heat exchanger clogged with debris. Internal bypass valve damaged or clogged with debris. Your spa thermometer is not reading the correct temperature. Air blower is running. Venturi air inlets are open. It is very cold outside. Spa pump is not running. | Clean entire filtering system and or replace filter element. Inspect & clean pump impeller. Adjust all plumbing valves. Repair suction air leaks, grease pump lid O-ring. Shut off air blower and or Venturi inlets that allow air turbulence in the spa. Use a cover while heating the spa. Outside air temp. too cold. Set spa pump timer for longer time. Call your dealer for advice. Call the factory for advice.                                                                                                                                                                                  |
| "Pool is heating very slowly.<br>Pool is not getting up to temperature."                                                                                                                         | "Low or restricted water flow through heater. Dirty or worn filters or clogged lint traps. Clogged filter pump impeller. Improper plumbing valve settings. Suction leak allowing air into the water flow. It is cold outside. Pool pump timer is not set for a long enough running period. Pool is not covered. High wind speed over pool. Shaded pool area."                                                                                                                                                                                                                | Clean entire filtering system and or replace filter element. Inspect & clean pump impeller. Adjust all plumbing valves. Repair suction air leaks, grease pump lid O-ring. Use a pool cover. Place a wind break around pool. Set pool pump timer longer. Call your dealer for advice. Call the factory for advice.                                                                                                                                                                                                                                                                                       |


| Problem or Symptoms                                                                                                                                   | Possible Cause                                                                  | Corrective Action                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
|-------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Higher than Normal Head Pressure, lower than normal suction pressure with high superheat and very cold or frosty distributor tubes, may have no Alarm | TXV stuck closed.                                                               | 1. Disconnect TXV bulb from suction line (SL), have it in your hand, if pressures go back to normal, then reinstall the bulb on suction line (it may have some debris stuck in the port). For adjustable TXVs open adjustable valve, it may remove the debris and set it back to original position. 2. If (1) does not work, recover the charge, remove bulb from SL, unscrew TXV head, shake it, if rattles, replace head (PN KT-45-ZGA), if not, replace TXV and filter dryer and charge appropriately. |
| Lower than Normal Head Pressure, higher than normal suction pressure with cold suction line and compressor and no superheat, may have no Alarm.       | TXV stuck open.                                                                 | 1. Check to see if TXV bulb is firmly attached to suction line, if loose, attach firmly by tightening the clamp over the bulb and suction line. 2. If (1) above does not work, reclaim charge and replace TXV and filter dryer with nameplate charge.                                                                                                                                                                                                                                                     |
| Unusually higher than normal current.                                                                                                                 | TXV stuck closed/partially closed, insufficient water flow, system overcharged. | See Possible Cause column for: TXV stuck closed, Insufficient water flow, and Unit overcharged.                                                                                                                                                                                                                                                                                                                                                                                                           |
| Low current with high superheat.                                                                                                                      | Unit undercharged.                                                              | Find source of refrigerant leak and fix. Pull vacuum and charge.                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Unit runs, but breaker trips continuously.                                                                                                            | Electrical issue.                                                               | Contact certified electrician.                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |

| Problems and Corrective Action (3 Phase Units Only)                                                                                                                                                      |                                                                                                                                       |                                                                                                                                                                    |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Problem or Symptoms                                                                                                                                                                                      | Possible Cause                                                                                                                        | Corrective Action                                                                                                                                                  |
| Unable to turn Heat Pump ON. Display is Blank. Unit will NOT start.                                                                                                                                      | Incorrect Wiring.                                                                                                                     | Check the Light on Phase Monitor inside the electrical box. If red, switch two of the Input wires. Any two of the three can be switched.                           |
|                                                                                                                                                                                                          | Faulty Phase Monitor.                                                                                                                 | Call dealer or factory for advice before attempting to replace parts. Replace Phase Monitor.                                                                       |
|                                                                                                                                                                                                          | Loose wire on Phase Monitor, either from the supply input power or the output side.                                                   | Check the Light on Phase Monitor inside the electrical box. If the Light is Red, fix the supply power loose end. If the Light is green, fix the output loose wire. |
| Compressor making a loud or unusual noise or sounds during operation. Fan is turning, no cool air discharge out of top of heater. Unit ON, and Set Temperature is above Actual, but Unit is not heating. | Compressor running Backwards. This usually happens if the compressor wire harness is disconnected for possible repair or replacement. | Switch any two of the three wires on the compressor side of the Contactor.                                                                                         |


[BLANK PAGE]

# REPLACEMENT PARTS


## Illustrated Parts View



**DETAIL B – Single Phase**



**DETAIL B – Three Phase**



## Parts List

| ITEM | PART NO. | DESCRIPTION                                                             |
|------|----------|-------------------------------------------------------------------------|
| 1    | 473665   | Probe Thermister Defrost Sensor                                         |
| 2    | 470284   | Nut, J-Clip                                                             |
| 3    | 473285   | Nut, 1/4 - 20 S/S Acorn                                                 |
| 4    | 470281   | Nut, U-Clip                                                             |
| 5    | 473732   | Wire Harness, Emerson Compressor (1-3PH-60Hz)                           |
|      | 474009   | Wire Harness, Compressor (1PH-50Hz)                                     |
|      | 474010   | Wire Harness, Danfoss Compressor (3PH Models)                           |
| 6    | 473734Z  | Compressor Scroll ZP83 (Models 120, 120 H/C, 140, 140 H/C)              |
|      | 473735Z  | Compressor Scroll ZP70 (Model 110)                                      |
|      | 474011Z  | Compressor Kit, Scroll ZP83 (3PH Models 120C, 140C)                     |
|      | 473780Z  | Compressor Scroll HLJ072 (Model 90I)                                    |
|      | 474081Z  | Compressor Scroll HLJ083 (Model 100I)                                   |
|      | 474241Z  | Compressor Scroll ZP61 (Model 90)                                       |
|      | 474291Z  | Compressor Scroll ZP49 (Model 70)                                       |
| 7    | 473295   | Fender Washer                                                           |
| 8    | 473736   | Compression Isolation Kit, Grommet and Spacer (1 Set)                   |
| 9    | 473745   | Bolt 5/16 - 18 X 1.75" S/S                                              |
| 10   | 98219800 | Bolt 5/16 - 18 X 1" S/S                                                 |
| 11   | 473121   | Drier (All Models except 120 H/C, 140 H/C)                              |
|      | 473139   | Drier (Models 120 H/C, 140 H/C)                                         |
| 12   | 470441   | Fan Guard Fastener Kit                                                  |
| 13   | 071406   | Nut, 1/4 - 20 Hex S/S                                                   |
| 14   | 472734   | Bezel, Control Board w/ Label                                           |
| 15   |          | Auto Heat Control Board, High                                           |
| 16   | 473603   | Pump Contactor AutoHeat (Models 70, 90, 110, 120, 120 H/C, 140, 140H/C) |
| 17   | 473150   | Fan Relay                                                               |
|      | 474016   | Fan Relay (3PH-50Hz only)                                               |
| 18   | 473155   | Transformer                                                             |
|      | 473790   | Transformer (3PH-50Hz only)                                             |
| 19   | 473422   | Wire Harness Terminal Block - Fan, Compressor                           |
| 20   | 473315   | Wire Harness Terminal Block - Sensors                                   |
| 21   | 473731   | Capacitor (All Models except 120C, 100I)                                |
|      | 473154   | Capacitor (3-Phase Models 120C, 140C)                                   |
|      | 470146   | Capacitor (Model 100I)                                                  |
| 22   | 473778   | Contactor, Heat Pump                                                    |
| 23   | 475112   | Wire Harness, Main (All Single Phase Models)                            |
|      | 474021   | Wire Harness, Main (3-Phase Models 120C, 140C)                          |
|      | 474031   | Wire Harness, Main (3-Phase Model 90I only)                             |
| 24   | 473742   | Panel, Front Right, 36" Almond                                          |
|      | 474194   | Panel, Front Right, 36" Black                                           |
|      | 473431   | Panel, Front Right (Model 100I only)                                    |
|      | 473412   | Panel, Front Right (Models 70, 90I, 90)                                 |
|      | 474265   | Panel, Front Right (Models 70 Black, 90 Black)                          |
| 25   | 470159   | Screw #10 x .75" Pan Head Phillips, Almond                              |
|      | 470198   | Screw #10 x .75" Pan Head Phillips, Black Head                          |
| 26   | 470161   | Screw #10 x 1" Button Head Torx, Almond Head                            |
|      | 474197   | Screw #10 x 1" Button Head Torx, Black Head                             |

| ITEM | PART NO. | DESCRIPTION                                                                  |
|------|----------|------------------------------------------------------------------------------|
| 27   | 473755   | Panel, Front Left, w/ Decal, 36" Almond                                      |
|      | 474196   | Panel, Front Left, w/ Decal, 36" Black                                       |
|      | 474202   | Panel, Front Left, w/ Decal (Model 100I only)                                |
|      | 474203   | Panel, Front Left, w/ Decal (Models 70, 90I, 90)                             |
|      | 474267   | Panel, Front Left, w/ Decal, 24" Black                                       |
| 28   | 473773   | HP Top                                                                       |
|      | 474193   | HP Top, Black                                                                |
| 29   | 473786   | Guard, Fan                                                                   |
| 30   | 470439   | Nut, #10-32 SS corn                                                          |
| 31   | 473785   | Fan Motor w/ Acorn Nut Kit                                                   |
|      | 474030Z  | Fan Motor w/ Acorn Nut Kit (Model 90I only)                                  |
|      | 474323Z  | Fan Motor w/ Acorn Nut Kit (Mdl 140, 140C, 140 H/C)                          |
| 32   | 473783   | Fan Blade (60Hz)                                                             |
|      | 474230   | Fan Blade (50Hz)                                                             |
|      | 474322   | Fan Blade (Models 140 and 140 H/C only)                                      |
| 33   | 470137   | Tie Down Bracket                                                             |
| 34   | 471566   | Probe Thermister - Water Temperature                                         |
| 35   | 473606   | Water Pressure Switch Boot                                                   |
| 36   | 473605   | Water Pressure Switch                                                        |
| 37   | 473992   | Titanium Heat Exchanger                                                      |
|      | 472736   | Titanium Heat Exchanger (Models 100I, 90)                                    |
|      | 472737   | Titanium Heat Exchanger (Models 70, 90I)                                     |
| -    | 474270Z  | Heat Pump Coil Repair Kit [Not Shown]                                        |
| 38   | 473774Z  | Water Bypass Manifold w/ 2 Street Elbows                                     |
| 39   | R172305  | Water Bypass Check Valve                                                     |
| 40   | 473381   | Union PVC 2"                                                                 |
| 41   | 473656   | Switch, Low Pressure                                                         |
| 42   | 473744   | Switch, High Pressure                                                        |
| 43   | 473787   | Thermostatic Expansion Valve (Models 120, 120C, 90I)                         |
|      | 473999   | Thermostatic Expansion Valve (Models 120HC, 110)                             |
|      | 474248   | Thermostatic Expansion Valve (Model 100I)                                    |
|      | 474242   | Thermostatic Expansion Valve (Models 70, 90)                                 |
|      | 474327   | Thermostatic Expansion Valve (Mdl 140, 140C, 140 H/C)                        |
| 44   | 473657   | Titanium Water Coil Tie Down Strap (2 on Model 70, 90I, 1 on Model 90, 100I) |
|      | 473772   | Titanium Water Coil Tie Down Strap (1 on Models except 90I)                  |
|      | 473789   | Titanium Water Coil Tie Down Strap (1 on Models except 70, 90, 90I, 100I)    |
| 45   | 474089   | Phase Monitor                                                                |
| -    | 473135   | Reversing Valve (Model 120HC) [Not shown]                                    |
| -    | 473432   | Reversing Solenoid (Model 120HC) [Not shown] for Heat Cool Only              |
| -    | 472734   | Auto Set Board Bezel LBL Kit [Not Shown]                                     |
| -    | 474237   | Clip Retension Comp. Pwr. [Not Shown]                                        |
| -    | 474270Z  | Leak Repair Kit [Not Shown]                                                  |
| -    | 474321   | 3 IN Receiver [Not Shown]                                                    |
| -    | 473054Z  | Coil Guard [Not Shown]                                                       |

## SAVE THESE INSTRUCTIONS



1620 HAWKINS AVE., SANFORD, NC 27330 • (919) 566-8000  
10951 WEST LOS ANGELES AVE., MOORPARK, CA 93021 • (805) 553-5000  
WWW.PENTAIRPOOL.COM

All Pentair trademarks and logos are owned by Pentair or one of its global affiliates. Pentair Aquatic Systems™, IntelliFlo®, UltraTemp®, EasyTouch®, IntelliTouch®, SunTouch® and Eco Select® are trademarks and/or registered trademarks of Pentair Water Pool and Spa, Inc. and/or its affiliated companies in the United States and/or other countries. Unless expressly noted, names and brands of third parties that may be used in this document are not used to indicate an affiliation or endorsement between the owners of these names and brands and Pentair Water Pool and Spa, Inc. Those names and brands may be the trademarks or registered trademarks of those third parties. Because we are continuously improving our products and services, Pentair reserves the right to change specifications without prior notice. Pentair is an equal opportunity employer.

© 2015 Pentair Water Pool and Spa, Inc. All rights reserved. This document is subject to change without notice.



P/N 474099 REV. M 1/13/15

